

UL Online Certifications Directory

[OCD Home](#) [Quick Guide](#) [Contact Us](#) [UL.com](#)

UTRZ.GuideInfo Power-supply Units

[Page Bottom](#)

[Signal and Fire Alarm Equipment and Services] Power-supply Units

[See General Information for Signal and Fire Alarm Equipment and Services](#)

USE

This category covers power supply units intended for application as components of fire-protective signaling systems.

PRODUCT MARKINGS

Each product is marked to indicate its intended use. This consists of a specific use description as indicated in the individual Listings.

ADDITIONAL INFORMATION

For additional information, see Signal and Fire Alarm Equipment and Services ([SYKJ](#)) and Fire Protection Equipment ([AAFP](#)).

REQUIREMENTS

The basic standard used to investigate products in this category is [UL 1481](#), "Power Supplies for Fire-Protective Signaling Systems."

UL MARK

The Signaling Listing Mark of Underwriters Laboratories Inc. on the product or on the smallest unit container in which the product is packaged is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Signaling Listing Mark for these products includes the UL symbol with the word "SIGNALING" above the UL symbol and the word "LISTED" below the UL symbol (as illustrated in the Introduction of this Directory), a control number, and the product name "Fire Alarm Equipment" or "Fire Alarm Subassembly."

The Listing Mark for fire alarm equipment may include the designation "___ of ___." The first space is stamped with the number indicating the position that the panel occupies in the series of panels constituting the fire alarm equipment. The second space is stamped with the total number of units in the fire alarm equipment.

When applicable, the Security Mark is also included. The combined Signaling/Security Listing Mark consists of the Signaling Mark elements detailed above and the word "SECURITY" above the UL symbol. The product name is "Fire Alarm and Security Equipment" or "Fire Alarm and Security Subassembly."

Some of these products are also Listed under other Signaling and Energy Management, Information Technology or Telephone categories. When applicable, the product name may include "and Hospital Signaling and Nurse Call," "and General Signaling," "and Emergency Signaling," "and Enclosed Energy Management," "and Information Technology" or "and Telephone," as appropriate (e.g., "Fire Alarm and Telephone Equipment").

The product name may be abbreviated as follows: The word "Type:" followed by the appropriate Type Code (as shown below), additionally followed by "Subassembly," as applicable.

Type Codes:

S - Security Equipment

F - Fire Alarm Equipment

HN - Hospital Signaling and Nurse Call Equipment

G - General Signaling Equipment

E - Emergency Signaling Equipment

EM - Enclosed Energy Management Equipment

IT - Information Technology Equipment

T - Telephone Equipment

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

