



## AMCXC.S4019 Central and Monitoring Station Burglar Alarm System Units

[Page Bottom](#)

### Central and Monitoring Station Burglar Alarm System Units

[See General Information for Central and Monitoring Station Burglar Alarm System Units](#)**DIGITAL SECURITY CONTROLS, DIV OF TYCO SAFETY PRODUCTS CANADA LTD**

S4019

3301 LANGSTAFF RD  
CONCORD, ON L4K 4L2 CANADA

Accessory Module (Ethernet Communicator) for Central and Monitoring Station Fire and/or Burglary, and Household Fire and/or Burglary, Models T-Link TL250, T-Link TL300.

Central Station Alarm Units, Input: 16.5 V ac, 60 Hz, 40 VA (using Class 2 limited energy transformers). DSC Series: Models PC1864, PC1832, PC1616.

Control unit accessory, Model GS3055-I GSM-GPRS Interface, intended for supplementary use only with separately Listed control units as indicated in the installation instructions.

Control unit accessories, Models GS3055-I and GS3060 GSM-GPRS Interfaces, Fire Alarm and Security Equipment, classified as a passive communication system with level P2 line security for use only with separately Listed control units as indicated in the installation instructions. Internal 12V, minimum 1.2 AH rechargeable battery is required for Low Power Mode (JP3 OFF); Model GS-BOOST Telco Voltage Booster, used only in conjunction with Model GS3060 when interfacing with alarm control panels that require a higher simulated Telco line voltage.

Control unit accessory, Model 3G3070 GSM-GPRS/3G Interface, Fire Alarm and Security Equipment, classified as a passive communication system with level P2 line security for use only with separately Listed control units as indicated in the installation instructions. Internal 12V, minimum 1.2 AH rechargeable battery is required for Low Power Mode (JP3 OFF).

Subscribers' unit accessories, Keypads, Models LCD5511, LED5511, PK5500, PK5501, PK5508, PK5516.

Control unit accessories, IP/GSM-GPRS Dual Alarm Communication Interface, Models TL260GS, TL260GS-SM, TL260GS-RS, TL2603GR, TL2603G; GSM-GPRS Alarm Communication Interface, Models GS2060, GS2060-SM, GS2060-RS, 3G2060R, 3G2060; IP Alarm Communication Interface, Models TL260, TL260R, TL260-SM, TL260-RS; classified as transmitting modules in an Active (A1-A4) communication system, or in a Passive (P1-P3) communication system (may be used in conjunction with a Listed DACT), for use only with DSC's separately Listed control units Models PC1864, PC1832, PC1616 and central station receivers as indicated in the installation instructions.

Subscriber's Control Unit: Model PC4020 and accessories, Zone Expanders Modules: Models PC4108A, PC4116; Dual Dialler Communication Interface: Model PC4701; PGM Output Modules: Model PC4216; Keypad: Model LCD4501Z(T); Serial Output module: Models PC4401, KT4401VK; Power Supply Module, Models PC4204CX and PC4204CXCF.

[Last Updated](#) on 2012-05-10[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

Copyright © 2012 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2012 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

