

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-1273:0130

Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Digital Security Controls 95 Bridgeland Ave, Toronto, Ontario M6A 1Y7 Canada
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020
Email: dnita@tycoint.com

DESIGN: Models FSB-210B, -210BT photoelectric type smoke detectors. Units are intended to detect an abnormal amount of smoke density in the area in which it is installed and signal a compatible control panel during this condition. Models with suffix letter "T" employ a supplemental integral thermistor type heat sensor for use only as a supplement to the smoke detector. This thermal circuitry is NOT approved for use in lieu of required heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 8-12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as addressable photoelectric type smoke detectors for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires, which smolder for hours before bursting into flames. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

11-03-2005 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division