



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-1273:0520
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita, Dan 6474800504 Email: dan.nita@jci.com
DESIGN:	Model PG9920 wireless RF repeater. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	120 Vac, 60 Hz
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	<p>Listed as a wireless RF repeater for use with Listee's separately listed compatible household fire alarm control units. Refer to listee's Installation Instructions Manual for details. Model complies with the applicable requirements in UL 985, 6th Edition.</p> <p>Compatible Household Fire Alarm Control Unit:</p> <p>Tyco Safety Products Canada Ltd. - Models HS2128, HS2064, HS2032, and HS2016 (CSFM No. 7167-1273:0153); and Models HS3248, HS3128, and HS3032 (CSFM Listing No. 7167-1273:0507)</p> <p>Tyco Safety Products Canada Ltd. - Models IQ Pro and IQ Pro P (CSFM Listing No. 7167-1273:0516)</p> <p>Qolsys - Model IQPanel4 (CSFM Listing No. 7167-2142:0505)</p>
NOTES:	

8-17-22 DAL



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division