

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 5278-1273:0155 Page 1 of 1

**CATEGORY:** 5278 -- CARBON MONOXIDE DETECTORS

**LISTEE:** Digital Security Controls 95 Bridgeland Ave, Toronto, Ontario M6A 1Y7 Canada  
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020  
Email: dnita@tycoint.com

**DESIGN:** Model PG9913 wireless carbon monoxide detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 9 Vdc Energizer 522

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a wireless carbon monoxide detector for use with listee's separately listed fire alarm control panels Models HS2128, HS2064, HS2032 and HS2016 (CSFM No. 7167-1273:0153). This unit is approved for household use only. Refer to listee's Installation Instructions Manual for details.

**NOTE:** Carbon Monoxide detectors are not intended/suitable for fire and smoke detection.

**XLF:** 5278-1667:0115

06-12-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division