

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7273-1273:0156 Page 1 of 1

**CATEGORY:** 7273 -- SMOKE DETECTOR FOR HAZARDOUS LOCATIONS

**LISTEE:** Digital Security Controls 95 Bridgeland Ave, Toronto, Ontario M6A 1Y7 Canada  
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020  
Email: dnita@tycoint.com

**DESIGN:** Models 3G4000, 3G4000RF GSM-GPRS/3G Alarm Communication Interface. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 9-14 Vdc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as alarm communication interface devices for use with a separately listed household fire alarm control units. Authority having jurisdiction shall be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Burglary and other non-fire functions were not examined.

11-12-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division