

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1273:0161 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Digital Security Controls 95 Bridgeland Ave, Toronto, Ontario M6A 1Y7 Canada
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020
Email: dnita@tycoint.com

DESIGN: Model 3G4010CF RF Communicator (GSM-GPRS/3G) signaling device. It is intended for use as a standalone communication technology (standalone unit). It may also be used as a backup communication technology in conjunction with a DACT. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 V, 50/60 Hz, 0.3 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as communicator signaling device for use with a separately listed fire alarm control unit. Refer to listee's Installation Instruction Manual for details.

06-03-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division