

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7167-1273:0139

Page 1 of 1

CATEGORY: 7167 -- CONTROL UNIT (HOUSEHOLD)

LISTEE: Digital Security Controls 95 Bridgeland Ave, Toronto, Ontario M6A 1Y7 Canada
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020
Email: dnita@tycoint.com

DESIGN: Models SCW9055-433, SCW9055D-433, SCW9055G-433, SCW9055I-433, SCW9055D-SM-433, SCW9055G-SM-433, SCW9055I-SM-433, SCW9057-433, SCW9057D-433, SCW9057G-433, SCW9057I-433, SCW9057D-SM-433, SCW9057G-SM-433, and SCW9057I-SM-433 short range low power RF and hardwire systems with integrated sounder, combination household fire and burglary alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

TL2553G-SM-NA, TL2553G-NA Communicator	IP/GSM Dual Alarm
*TL2553GR-E, *TL2553G-E	*IP/3G Dual Alarm Communicator
3G2055-SM-NA, 3G2055-NA	GSM Alarm Communicator
*3G2055R-E, *3G2055-E	*3G Alarm Communicator
TL255-SM-NA, TL255-NA, *TL255R-E, *TL255E	IP Alarm Communicator

RATING: 120VAC, 60Hz, 0.20A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as combination household fire and burglary alarm control units for use with separately listed compatible initiating and indicating devices. This control unit and the indoor siren can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2010 Edition with California amendments. Refer to listee's Installation Instructions Manual for details.

NOTE: 1. For household system, Fire Alarm Verification Feature (Delay of fire alarm signal) shall not be used in California.

2. Burglary and other non-fire functions were not examined.

*Rev 07-06-16 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division