



INCERT CERTIFICATE

C-035-1415/b



Issued 13-03-2023
Expiry date 25-05-2024

Replaces C-035-1415/a
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description:

Power Series Pro Model HSM3350 Alarm System
Power Supply

Trademark:

DSC/Tyco

Type designation:

HSM3350

Hardware / Software:

UA720 Rev. 03 / 1.03

Placed on the market under the name or trademark of:

Name of the manufacturer:

Digital Security Controls, a div. of Tyco Safety
Products Canada Ltd.

Address:

3301 Langstaff Road

City:

L4K 4L2 CONCORD

Country:

Canada

This certificate is granted to:

Name of the certificate holder:

Digital Security Controls, a div. of Tyco Safety
Products Canada Ltd.

Address:

3301 Langstaff Road

City:

L4K 4L2 CONCORD

Country:

Canada

Ron Scheepers
Managing director

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Category: Auxiliary power supply

Security grade: 3

Environmental class: II

Equipment class: Fixed

Power supply type: A

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Tyco International De Mexico S De R.L. De C.V.

Antonio Meucci Yg Gonzalez Camarena 10002

Parque Industrial La Ventana

87569, Matamoros

Mexico

Product inspection location:

AnB Rimex SA

Rue de l'Abbaye 89

4040, Herstal

Belgium

Documentation lodged for this INCERT certificate

Test Reports:

- Telefication: 180600121-001-Ver 1.00, 03 December 2018
- Telefication: 180600121-005-Ver 1.00, 19 November 2018
- Telefication: 180600139-ENV-Ver.1.00, 03 December 2018
- Nemko Canada Inc.: HS3128_HSC3020C EN50130-4 Report 351820-2TRFEMC, 31 August 2018

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1 February, 2018

Applied Standards

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-6	October, 2017
EN 50131-1+A1+A2	May, 2017

The product as described in this certificate includes the following type designations

- Product description: Power Series Pro Model HSM3350 Alarm System Power Supply
- Trademark: DSC/Tyco
- Type designation: HSM3350
- Hardware version: UA720 Rev. 03
- Software version: 1.03