

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1273:0135 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, Ontario L4K 4L2 Canada
Contact: Dan Nita (647) 480-0430 Fax (905) 760-3020
Email: dnita@tycoint.com

DESIGN: Models T-Link TL250 and T-Link TL-300 Ethernet communicator (LAN, WAN, Internet). It forms part of a central station fire and burglar alarm system which employs 10/100BaseT Ethernet communication network as its signaling medium.

The T-Link TL250 is intended to be connected inside the same enclosure as the control unit through the PC-Link communication bus. The unit is powered by the auxiliary (AUX) output from the control panel and it communicates via the Ethernet connection through the LAN/WAN/internet network.

The T-Link TL300 is housed in its own enclosure and can connect to any separately listed control unit directly using the telephone connection interface available on the board or four separate zone inputs or through an eight zone expander board DSC, Model PC5108.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary Operating Supply: 12 V dc nominal (provided by the control panel)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, date of manufacture and UL label.

APPROVAL: Listed as a network communicator for use with separately listed compatible fire alarm control units



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division