

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1273:0500 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, Ontario L4K 4L2 Canada
Contact: Dan Nita (647) 480-0430 Fax (905) 760-3020
Email: dnita@tycoint.com

DESIGN: Models TL2803GRE, TL2803GE IP/3G/GSM-GPRS Dual Alarm Communicators Models 3G2080RE, 3G2080E 3G/GSM-GPRS Alarm Communicators, Models TL280RE, TL280E IP Alarm Communicators and Model PCL-422 Communicator expansion interface board.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as alarm communication interface devices for use with a separately listed fire alarm control unit. Refer to listee's Installation Instruction Manual for details.

7-15-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division