



<b>LISTING No.:</b>	7300-1273:0126
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
<b>LISTEE:</b>	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita,Dan (905) 760-3020 Email: dan.nita@jci.com
<b>DESIGN:</b>	<p>Model SG-System III digital alarm communicator receiver with subassemblies *SG-DRL3, SG-DRL3L, SG-DRL3-2L, SG-DRL3E-2L , and SG-DRL3-IP. . Unit is a multi-platform digital telephone receiver intended for remote monitoring of commercial fire and burglary central station receiving applications. Refer to listee's data sheet for additional detailed product description and operational considerations.</p> <p>System components:</p> <ul style="list-style-type: none"> <li>SG-DRL3, SG-DRL3E, SG-DRL3-2L,</li> <li>SG-DRL3E-2L , SG-DRL3-IP;                      Digital Receiver Line Cards</li> <li>SG-CPM3;    Central Processor Module</li> <li>SG-PSU3;    Power Module Supply</li> <li>SG-PSC3;    Power Monitor Board</li> <li>SG-DC/DC3 DC/DC;                                  Converter Card</li> <li>SG-UIB3;    User Interface Board</li> <li>CPU1150,CPU DMP206,SCS-PRT;                  Printer</li> <li>MLR2-CL/-CMMSG-IMRAK;                          Cabinet</li> <li>1400 or Equivalent;                                  Cabinet</li> <li>SG-MLRF3;    Receiver Subrack</li> </ul>
<b>RATING:</b>	120 V, 60 Hz, 2.5 A
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as digital alarm communicator receiver for central station receiving applications. Authority having jurisdiction shall be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

**NOTES:**

\*Rev 07-18-12 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/04/2022**

**Listing Expires: 06/30/2022**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division