



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-1273:0512
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita, Dan (647) 480-0430 (905) 760-3020 Email: dan.nita@jci.com
DESIGN:	Models PG9WLSHW8 and *PG9HRDW8 PowerG Hardwired to Wireless Converter. Units allows inputs from hardwired initiating devices to be sent using PowerG wireless proprietary protocol to a compatible wireless alarm system. *Model PG9HRDW8 is identical in construction and functionality with model PG9WLSHW8 except model PG9HRDW8 is using a larger size plastic enclosure. Intended for indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	*Primary: 120 VAC, 60 Hz, 1.2 A *Secondary: 18 VDC, 2.22 A *Power Supply Module: Models SOY-1800222-NA, PGWLSH40A, HS40WPSNA, or HS40WPSA (plug-in type)
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and UL label.
APPROVAL:	Listed as a control unit accessories for use with separately listed compatible household fire alarm control unit and separately listed compatible smoke detectors and CO detectors. Compatible Fire Alarm Control Units: Qolsys - Models IQPanel2 (CSFM Listing No. 7167-2142:0501) and *IQPanel4 (7167-2142:0505) Compatible Smoke Detectors: System Sensor 2W-B and 2WT-B (CSFM Listing No. 7272-1653:0152) and 2WTA-B (CSFM Listing No. 7272-1653:0164) Refer to listee's Installation Instruction Manual for details.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

NOTES:

Rev.12-16-21
VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division