



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7300-1273:0500
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
<b>LISTEE:</b>	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita,Dan (647) 480-0430 (905) 760-3020 Email: dan.nita@jci.com
<b>DESIGN:</b>	Models TL2803GRE, TL2803GE IP/3G/GSM-GPRS Dual Alarm Communicators Models 3G2080RE, 3G2080E 3G/GSM-GPRS Alarm Communicators, Models TL280RE, TL280E IP Alarm Communicators and Model PCL-422 Communicator expansion interface board.  Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	12 Vdc
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating and UL label.
<b>APPROVAL:</b>	Listed as alarm communication interface devices for use with a separately listed fire alarm control unit. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

7-15-16 dc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/03/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division