



# INCERT CERTIFICATE

## C-035-1412/b



Issued 13-03-2023  
Expiry date 25-08-2027

Replaces C-035-1412/a  
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description:

Power Series Pro Model HSM3408 Alarm System  
Zone Expander

Trademark:

DSC/Tyco

Type designation:

HSM3408

Hardware / Software:

UA719 Rev. 03 / 1.02

Placed on the market under the name or trademark of:

Name of the manufacturer:

Digital Security Controls, a div. of Tyco Safety  
Products Canada Ltd.

Address:

3301 Langstaff Road

City:

L4K 4L2 CONCORD

Country:

Canada

This certificate is granted to:

Name of the certificate holder:

Digital Security Controls, a div. of Tyco Safety  
Products Canada Ltd.

Address:

3301 Langstaff Road

City:

L4K 4L2 CONCORD

Country:

Canada

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Category: Interface

Security grade: 3

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Factory location:

Tyco International De Mexico S De R.L. De C.V.

Antonio Meucci Yg Gonzalez Camarena 10002

Parque Industrial La Ventana

87569, Matamoros

Mexico

Product inspection location:

AnB Rimex SA

Rue de l'Abbaye 89

4040, Herstal

Belgium

**Documentation lodged for this INCERT certificate**

Test Reports:

- Nemko Canada Inc.: HS3128\_HSC3020C EN50130-4 Report 351820-2TRFEMC, 31 August 2018
- Nemko Canada Inc.: HS3128\_HSC3020CP EN50130-4 Report 351713-2TRFEMC, 20 June 2018
- Telefication: 180600139-001-Ver.3.00, 18 April 2019
- Telefication: 180600139-ENV-Ver.1.00, 03 December 2018
- Telefication: 180600139-009-Ver.3.00, 18 April 2019

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1

February, 2018

**Applied Standards**

EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-10	June, 2014
EN 50130-4+A1	October, 2014
EN 50131-6	October, 2017
EN 50131-3	March, 2009

**The product as described in this certificate includes the following type designations**

- Product description: Power Series Pro Model HSM3408 Alarm System Zone Expander
- Trademark: DSC/Tyco
- Type designation: HSM3408
- Hardware version: UA719 Rev. 03
- Software version: 1.02