



# INCERT CERTIFICATE C-035-1728



Issued 19-06-2024 Replaces  
Expiry date 13-02-2026 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: I&HAS Control Unit  
Trademark: Tyco/DSC  
Type designation: IQ Pro  
Serial No: N/A  
Hardware / Software: 0C / 4.3.0n  
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Digital Security Controls, a division of Tyco  
Safety Products Canada Ltd.  
Address: 3301 Langstaff Road  
City: L4K 4L2 Concord  
Country: CANADA

This certificate is granted to:

Name of the certificate holder: Digital Security Controls, a division of Tyco  
Safety Products Canada Ltd.  
Address: 3301 Langstaff Road  
City: L4K 4L2 Concord  
Country: CANADA

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

# CERTIFICATE

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

- Category: Central panel
- Security grade: 2
- Environmental class: II
- Equipment class: Fixed
- Power supply type: A
- SPT type: Z
- ATS category: DP1 and DP3 WiFi/WLAN and GSM  
SP2 and SP4 GSM

Factory location:

TYCO INTERNATIONAL DE MEXICO S DE R.L. DE C.V.  
ANTONIO MEUCCI YG GONZALEZ CAMARENA #  
10002/PARQUE INDUSTRIAL LA VENTANA

Matamoros  
Mexico

Product inspection location:

Tyco Security Products  
Voltaweg 20  
Echt  
The Netherlands

**Documentation lodged for this INCERT certificate**

## Test Reports:

- Kiwa Nederland B.V.: P000337730-001-Ver 1.00, 15 May 2024
- Kiwa Nederland B.V.: P000337730-002-Ver 1.00, 03 May 2024
- Kiwa Nederland B.V.: P000337730-003-Ver 1.00, 02 May 2024
- Kiwa Nederland B.V.: P000337730-004-Ver 1.00, 28 May 2024
- Nemko Canada Inc.: REP015666, 04 October 2023
- Nemko Canada Inc.: REP017262, 04 October 2023
- Kiwa Nederland B.V.: P000337730-005-Ver1.00, 17 May 2024

## Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1+A2	August, 2022
-------------	--------------

**Applied Standards**

EN 50131-3	March, 2009
EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-10	June, 2014
EN 50130-4+A1	October, 2014
EN 50131-6+A1	June, 2021
EN 50131-5-3	March, 2017
EN 50136-1+A1	November, 2018
EN 50131-1+A1+A2+A3	June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: I&HAS Control Unit
- Trademark: Tyco/DSC
- Type designation: IQ Pro
- Hardware version: 0C
- Software version: 4.3.0n
- Serial number: N/A

- Product description: I&HAS Control Unit
- Trademark: Tyco/DSC
- Type designation: IQ Pro P
- Hardware version: 0C
- Software version: 4.3.0n
- Serial number: N/A