




**Fig 1. Wiring Diagram for One Heating/Cooling System with One HS-EMS400 Thermostat**




**Warning! Do not remove the internal jumper (shunt). Connect to O or B terminal as specified by equipment. Do not connect to both O and B terminals.**

**Output Terminal Functions**


- |            |   |              |  |
|------------|---|--------------|--|
| LED1 ..... | Free light for status or function indication.                   | W1 .....     | Auxiliary heat is energized as back-up or emergency heat.                          |
| LED2 ..... | Free light for status or function indication.                   | Y1 .....     | Compressor is energized with a call for heating or cooling.                        |
| CLK1 ..... | Use with dry contact relay for alternate set points.            | G .....      | Fan is energized with a call for heating or cooling or by pressing the fan button. |
| CLK2 ..... | Use with dry contact relay for alternate set points.            | R .....      | Independent switching voltage.   |
| RS2 .....  | To Outdoor/Indoor remote sensors.                               | 24V .....    | 24 VAC Hot from equipment transformer.   |
| RS1 .....  | To Outdoor/Indoor remote sensors.                               | 24V(c) ..... | 24 VAC Common from equipment transformer.  |
| RS+V ..... | To Outdoor/Indoor remote sensors and to Escort5580TC/VPM5580TC. | O .....      | Energizes the reversing valve continuously in cool mode.                           |
| X2 .....   | To Escort5580TC/VPM5580TC.                                      | B .....      | Energizes the reversing valve continuously in heat or off mode.                    |
| X1 .....   | To Escort5580TC/VPM5580TC.                                      |              |  |

**Fig 2. Powering an HS-EMS400 Thermostat with a Stand-alone Transformer**



**Warning!:** Remove the internal jumper (shunt) before connecting the stand-alone transformer. Connect to O or B terminal as specified by equipment. Do NOT connect to both O and B terminals.

**Fig 3. Wiring Diagram for Multiple Heating/Cooling Systems with Multiple HS-EMS400 Thermostats**



**Warning! Connect Escort/VPM RS+V to first thermostat only. Do not remove the internal jumper (shunt). Connect to O or B terminal as specified by equipment. Do NOT connect to both O and B terminals.**

### Warranty

Digital Security Controls Ltd. warrants that for a period of twelve months from the date of purchase, the product shall be free of defects in material and workmanship under normal use and that in fulfillment of any breach of such warranty, Digital Security Controls Ltd. shall, at its option, repair or replace the defective equipment upon return of the equipment to its repair depot. This warranty applies only to defects in parts and workmanship and not to damage incurred in shipping or handling, or damage due to causes beyond control of Digital Security Controls Ltd. such as lightning, excessive voltage, mechanical shock, water damage, or damage arising out of abuse, alteration or improper application of the equipment. The foregoing warranty shall apply only to the original purchaser, and is and shall be in lieu of any and all other warranties, whether express or implied and of all other obligations or liabilities on the part of Digital Security Controls Ltd. This warranty contains the entire warranty. Digital Security Controls Ltd. neither

assumes responsibility for, nor authorizes any other person purporting to act on its behalf to modify or to change this warranty, nor to assume for it any other warranty or liability concerning this product.

In no event shall Digital Security Controls Ltd. be liable for any direct, indirect or consequential damages, loss of anticipated profits, loss of time or any other losses incurred by the buyer in connection with the purchase, installation, operation or failure of this product.

**WARNING: DSC Ltd. recommends that the entire system be completely tested on a regular basis. However, despite frequent testing, and due to but not limited to, criminal tampering or electrical disruption, it is possible for this product to fail to perform as expected.**

### FCC COMPLIANCE STATEMENT

**CAUTION: Changes or modifications not expressly approved by Digital Security Controls Ltd. could void your authority to use this equipment.**

This equipment generates and uses radio frequency energy and if not installed and used properly, in strict accordance with the manufacturer's instructions, may cause interference to radio and television reception. It has been type tested and found to comply with the limits for Class B device in accordance with the specifications in Subpart "B" of Part 15 of FCC Rules, which are designed to provide reasonable protection against such interference in any residential installation. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause interference to television or radio reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Re-orient the receiving antenna
- Relocate the alarm control with respect to the receiver
- Move the alarm control away from the receiver
- Connect the alarm control into a different outlet so that alarm control and receiver are on different circuits.

If necessary, the user should consult the dealer or an experienced radio/television technician for additional suggestions. The user may find the following booklet prepared by the FCC helpful: "How to Identify and Resolve Radio/Television Interference Problems". This booklet is available from the U.S. Government Printing Office, Washington, D.C. 20402, Stock # 004-000-00345-4.

# HS-EMS400 Single-Compressor Heat Pump Thermostat

Operating Instructions

## Introduction

The HS-EMS400 Digital Communicating Thermostat is designed to provide accurate control and display of room temperature. The thermostat normally displays room temperature, mode of operation (i.e. Day or Night), and whether Cooling or Heating is currently on. The six buttons on the front of the unit allow complete control of the thermostat. You may specify different Heating and Cooling setpoints, and change them easily by pushing a button. Temperature can be displayed in either °C or °F. The thermostat also allows you to select either continuous fan operation, or fan operation only during operation of the heating/cooling device(s).

## Modes of Operation

Select the desired mode of operation by toggling the MODE button:

- \* —indicates Cooling system only. “COOL” is displayed for 5 seconds.
- ♦ —indicates Heating system only. “HEAT” is displayed for 5 seconds.
- ♦ \* —indicates both the Heating and Cooling (automatic). “AUTO” is displayed for 5 seconds).
- \* (flashing)—indicates Cool is ON.
- ♦ (flashing)—indicates Heat is ON.

Eht - indicates Emergency Heat

OFF—shuts off thermostat. Heating and Cooling systems will not operate. Fan operation is still possible.

**Caution:** Avoid using the OFF mode during cold weather to prevent damage from freezing.

## Temperature Control

### Cooling: \*

Select the temperature you want the thermostat to maintain while in Cool mode, press the mode button until Cool mode is selected, then press the ▲ or ▼ buttons until the desired temperature is displayed. The cooling setpoint temperature is displayed for 5 seconds.

### Heating: ♦

Select the temperature you want the thermostat to maintain while in Heat mode, press the mode button until Heat mode is selected, then press the ▲ or ▼ buttons until the desired temperature is displayed. The heating setpoint temperature is displayed for 5 seconds.

### Auto: ♦ \*

The thermostat will automatically switch from heating to cooling as determined by the selected setpoints in heating and cooling.

**NOTE:** The thermostat will not allow less than 1 C (2 F) difference between the heating and cooling setpoints.

## Fan Control \*≈


The Fan will come on automatically when the system is operating, but there is no indication of this on the display. To select continuous Fan operation, press the FAN button and the display will show \*≈. This is recommended for electronic air cleaners and continuous ventilation requirements.

## Outdoor (ODT) Button

When the outdoor temperature sensor option is connected to your thermostat, you can display the current outdoor temperature by pressing the button. If this option is not connected, the thermostat will display \_\_ ❗ with no numbers.

## Emergency Heat Indication

The center LED at the top of the thermostat lights when the system calls for Emergency (Auxiliary) Heat.



## Day/Night Button

The Day/Night button is used to select the Occupancy setting. When first installed, the thermostat is set to Day occupancy setting and the display will show the ⚙ symbol and the Day temperature. By pressing the Day/Night button you can change to the Night occupancy setting and the display will show the 🌙 symbol and the Night temperature. This button can be used to toggle between Day and Night modes. Within each mode the temperature can be modified. The thermostat will remember any new settings.

## Celsius/Fahrenheit

Simultaneously press ▲ and ▼ to toggle between Celsius ( C ) and Fahrenheit ( F ) temperature display.

## Optional Indoor/Outdoor Remote Sensors

The thermostat can accept indoor and outdoor remote temperature sensors (EMS-ITS and EMS-OTS) for monitoring of temperatures where these sensors are located.

Connecting indoor sensors disables the temperature sensor on the thermostat thereby increasing the flexibility of where the thermostat can be located. For temperature averaging over a large area, a minimum of two indoor sensors are required.

Indoor and outdoor sensors are available separately. For more details about installing these sensors, please refer to the Installation Instructions included with the sensors.

## Temperature Accuracy

Full accuracy is only achieved after the thermostat has been installed and powered for at least one hour.

## Power Failures

No battery is required to maintain the temperature setpoints in the case of a power loss, regardless of duration.