



UOJZ.S5404 Control Units, System

[Page Bottom](#)

Control Units, System

[See General Information for Control Units, System](#)**DIGITAL SECURITY CONTROLS, DIV OF TYCO SAFETY PRODUCTS CANADA LTD**

S5404

95 BRIDGELAND AVE
TORONTO, ON M6A 1Y7 CANADA

Model	Type Fire Alarm	Type Service	Type Signaling
SG-SYSTEM 5	CS (RU)	A, M, SS, WF	OT
SG-System I*	CS (RU)	A, M, SS, WF	DAC, OT
SG-System II*	CS (RU)	A, M, SS, WF	OT
SG-System III*	CS (RU)	A, M, SS, WF	DAC, OT
SG-System IV*	CS (RU)	A, M, SS, WF	DAC, OT

Subassemblies, Model(s) SG-DRL5-IP, SG-DRL5-IP-PAD, SG-CPM5, SG-SYS5EBUS, SG-PSU5-250, SG-PSU-600, SG-MLRF5 #

CS (RU) - Central Station System Type (Receiving Unit)

A - Automatic fire alarm: Thermostats, smoke detectors, etc.

M - Manual fire alarm: Manually-operated boxes

SS - Sprinkler Supervisory: Gate valves, water-level switches, temperature switches, carbon monoxide detectors, residential fire alarm control units, etc.

WF - Waterflow alarm: Waterflow switches

OT - Other Transmission Technologies

DAC - Digital Alarm Communicator

- Subassemblies are suitable for use for the SG-SYSTEM 5

* - OT-Other Technologies = Packet Switched Data Network.

Last Updated on 2014-09-30[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".