

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

LISTING No. 7167-1273:110 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Digital Security Control, 95 Bridgeland Ave., Toronto, Ontario, Canada M6A 1Y7\*  
Contact: Dan Nita (905) 760-3000 FAX (905) 760-3020

DESIGN: Models PC1555, PC580, P-48, P6B, PC5008, P6BM, PC1555MX and P-6BMX combination household fire and burglary alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PC1555, PC1555MX, 6B, PC580, P-48,	Control Unit
PC5008, P6BM, P-6BMX	Control Unit
PC1555RKZ, PRS6RKZ	Keypad
PC5506Z, PRS600Z, LCD5500Z, P832-LCDZ	Keypad
PC5508Z, P832-08Z, PC5502Z2, P832-02Z	Keypad
RM-1, EOLR-2, EOL-R-1	End-of-line Resistor

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

MARKING: Listee's name (DSC) or "Partner", model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm control units for use with separately listed compatible initiating and indicating devices.

These control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to listee's Installation Instructions Manual for details.

- NOTE:
1. For household system, **Fire Alarm Verification Feature** (Delay of fire alarm signal) shall not be used in California.
  2. Burglary and other non-fire functions were not examined.

\*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*