

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7300-1273:0132 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Digital Security Controls 95 Bridgeland Ave, Toronto, Ontario M6A 1Y7 Canada  
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020  
Email: dnita@tycoint.com

**DESIGN:** Model SG-System II central station receiver. Suitable for commercial and burglary central station receiving applications. These units allow acknowledgement and display of incoming signals as well as local trouble annunciation. Receiver contains one Ethernet line connection that can be used with 10/100 BaseT networks.

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Primary Operating Supply: 100-240 V, 50/60Hz, 0.7A  
Secondary Operating Supply: 100-240 V, 50/60Hz, 0.7A [Provided by a separately UL Listed power supply (UPS)]

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction, UL Standard 827 (Standard for Central Station Alarm Services).

**MARKING:** Listee's name, model designation, date of manufacture and UL label.

**APPROVAL:** Listed as a receiver unit for use with separately listed compatible central station fire alarm control units.

**NOTE:**

05-21-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division