

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7167-1273:0113

Page 1 of 1

**CATEGORY:** 7167 -- CONTROL UNIT (HOUSEHOLD)

**LISTEE:** Digital Security Controls 95 Bridgeland Ave, Toronto, Ontario M6A 1Y7 Canada  
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020  
Email: dnita@tycoint.com

**DESIGN:** Models PC4010, PC4010CF, PC4020, PC4020CF, P-864, P-864CF, P-16128, and 16128CF combination fire and burglary fire alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PC4010, PC4020, P-864, P-16128	Control Unit
LCD-4500, LCD-4500T	Keypads
LCD-4501, LCD-4501T, LCD-4510	Keypads
RPS400, RPS-400T, LCD400T, PRS400F	Keypads
LCD4521T, PRS400FT, LCD4520, LCD4521	Keypads
PC4108, P4108, PC4116, P4116	Zone Expander
PC4204, P4204	Power Supply/Relay Module
PC4216, P4216	Output Module
PC4001C, P4002C, P4003C	Enclosure
PC4400 RS232	Interface Module
PC4700, P4700, PC4701, P4701	Fire Module
PC4612A, P4612A	Zone Annunciators

**RATING:** 120 VAC, 12 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

**MARKING:** Listee's name (DSC) or "Partner", model number, electrical rating and UL label.

**APPROVAL:** Listed as combination household fire and burglary alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Burglary and other non-fire functions were not examined.

\*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division