

# INCERT CERTIFICATE

**Certificate No: C-035-1449**

In compliance with the procedure specified in RD\_014, Telefication declares that the stated alarm equipment complies with the Technical specifications as listed in this certificate.

Product description: **Wireless magnetic contact**  
Trademark: **Tyco**  
Type designation: **PG8312 (868)**  
Hardware / Software version: **90-209056 / JS-703622**

Manufacturer: **Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.**  
Address: **3301 Langstaff Road**  
City: **L4K 4L2 CONCORD**  
Country: **Canada**

This certificate is granted to:

Name: **Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.**  
Address: **3301 Langstaff Road**  
City: **L4K 4L2 CONCORD**  
Country: **Canada**

Expiry date: **24 July 2025**

This INCERT certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the full responsibility of the manufacturer.

Zevenaar, 25 July 2019



Jan Willem Verwoert  
Project Manager



## Remarks and observations

The following conditions are applicable:

Category: Wireless magnetic contact

Security grade: 2

Environmental class: IV

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2. Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Shanghai GES Information Technology Co., Ltd.

668 Lishizhen Road, Zhangjiang High-Tech Park

201203, Shanghai

China

Product inspection location:

AnB Rimex SA

Rue de l'Abbaye 89

4040, Herstal

Belgium

## Documentation lodged for this INCERT certificate

### Test Reports:

- Hermon Laboratories Ltd.: VISRAD\_EN.31129\_EN 50131-5-3\_868MHz, 03 December 2018
- ANPI asbl: bis-rec-1438-00\_Visonic\_Outdoor Magnetic Contact MC-312 PG2 (868 MHz) \_Class IV for SO2 test\_Hermon Labs, 24 September 2018
- Hermon Laboratories Ltd.: VISEMC\_EN\_30990\_868MHz, 07 August 2018
- Hermon Laboratories Ltd.: VISENV\_EN.31129, 09 October 2018
- Hermon Laboratories Ltd.: VISIAS\_EN 50131-2-6.31129, 05 November 2018
- Hermon Laboratories Ltd.: VISIAS\_EN 50131-6.31129, 05 November 2018
- Telefication B.V.: 190300051-001-Ver 2.00, 05 June 2019

### Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

## Technical Standards and Specifications

The product shows no non-compliances with:

T 031/A1

February, 2018

## Technical features and characteristics

The product includes the following features and characteristics:

**The product as described in this certificate includes the following type designations:**

- |                        |                           |
|------------------------|---------------------------|
| - Product description: | Wireless magnetic contact |
| - Trademark:           | Tyco                      |
| - Type designation:    | PG8312 (868)              |
| - Hardware version:    | 90-209056                 |
| - Software version:    | JS-703622                 |