



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7300-1273:0157
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
<b>LISTEE:</b>	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita,Dan (905) 760-3020 Email: dan.nita@jci.com
<b>DESIGN:</b>	<p>Model SG-System 5 control unit receiver. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:</p> <p>SG-DRL5-IP, SG-DRL5-IP-PAD;*IP Receiver cards</p> <p>*SG-DRL5, *SG-DRL5E, *SG-DRL5-2L, *SG-DRL5PAD;*POTS Receiver cards</p> <p>*SG-DRL5-ADPT;Adapter card</p> <p>SG-CPM5; Central Processing Module card</p> <p>SG-SYS5EBUS; Ethernet switch</p> <p>SG-PSU5-250, SG-PSU-600; Power Supply Unit module</p> <p>SG-MLRF5; Sub-rack assembly</p>
<b>RATING:</b>	120 Vac, 10 A
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating and UL label.
<b>APPROVAL:</b>	Listed as an alarm communicator receiver for central station receiving applications. Authority having jurisdiction shall be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	Burglary and other non-fire functions were not examined.

\*Rev 04-12-15 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/04/2022**

**Listing Expires: 06/30/2023**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division