CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7300-1273:0505
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita,Dan (905) 760-3020 Email: dan.nita@jci.com
DESIGN:	Model LE4010 LTE interface. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	9-14 Vdc
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating and UL label.
APPROVAL:	Listed as a interface for use with a separately listed fire alarm control unit. Refer to listee's Installation Instruction Manual for details.
NOTES:	Burglary and other non-fire functions were not examined.

01-11-18 gt

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/04/2022

Listing Expires: 06/30/2023

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division