



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7272-1273:0508
<b>CATEGORY:</b>	7272 - SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC
<b>LISTEE:</b>	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita,Dan (647) 480-0430 (905) 760-3020 Email: dan.nita@jci.com
<b>DESIGN:</b>	Model PG9936. Battery-operated, photoelectric, smoke-automatic fire detector with supplemental 135°F (57°C) fixed temperature sensor and 15 °F (8.3 °C) Rate of Rise temperature, audible signal and RF transmitter for open area protection. Each smoke detector is powered by three “AAA” Alkaline 1.5 volt batteries (4.5 V DC), 3 in series.  Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	(3) Duracell Procell PC2400 1.5VDC  (3) Eveready Energizer E92 1.5VDC
<b>INSTALLATION:</b>	In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as a photoelectric smoke/automatic fire detector for use with the CSFM following listed control units:  HS2128, HS2064, HS2032, and HS2016 (CSFM No. 7167-1273:0153) when connected to HSM2HOST9 wireless receiver.  WS900-19, and WS900-29 Wireless Alarm Systems (CSFM No. 7167-1273:0501), HS3128, HS3032 (CSFM No. 7167-1273:0507) when connected to HSM2HOST9 wireless receiver.  This unit is approved for household use only. Refer to listee's Installation Instructions Manual for details.
<b>NOTES:</b>	

01-04-2019 dcc



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/03/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division