



INCERT CERTIFICATE

C-035-1558/a



Issued 13-03-2023 Replaces C-035-1558
Expiry date 23-07-2027 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: I&HAS Power Supply
Trademark: DSC/Tyco
Type designation: HSM2204
Serial No: N/A
Hardware / Software: UA623 Rev.01 / Ver. 1.15
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.
Address: 3301 Langstaff Road
City: L4K 4L2 CONCORD
Country: Canada

This certificate is granted to:

Name of the certificate holder: Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.
Address: 3301 Langstaff Road
City: L4K 4L2 CONCORD
Country: Canada

Ron Scheepers
Managing director

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.

CERTIFICATE

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Category: Auxiliary power supply

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: A

EN compliant when installed in PC5003C or PC5006C enclosure.

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

TYCO INTERNATIONAL DE MEXICO S DE R.L. DE C.V.

ANTONIO MEUCCI YG GONZALEZ CAMARENA # 10002/PARQUE INDUSTRIAL LA VENTANA

87569, Matamoros

Mexico

Product inspection location:

AnB Rimex SA

Rue de l'Abbaye 89

4040 Herstal

Belgium

Documentation lodged for this INCERT certificate

Test Reports:

- Telefication B.V.: 20134032800rev2.0, 14 August 2014
- Nemko Canada Inc.: 238276-1TRFEMC, 05 July 2013
- Nemko Canada Inc.: 233462-1TRFEMC, 22 May 2013
- Telefication: 181001649-025-Ver 1.00, 25 March 2019
- Telefication B.V.: 200800715-009-Ver 1.00, 22 March 2021
- Telefication B.V.: 200800715-002-Ver.1.00, 05 May 2021

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1

February, 2018

Applied Standards

EN 50130-5

June, 2011

EN 50130-4+A1

October, 2014

EN 50131-6

October, 2017

EN 50131-1+A1+A2

May, 2017

The product as described in this certificate includes the following type designations

- Product description: I&HAS Power Supply
- Trademark: DSC/Tyco
- Type designation: HSM2204
- Hardware version: UA623 Rev.01
- Software version: Ver. 1.15
- Serial number: N/A

- Product description: I&HAS Power Supply
- Trademark: DSC/Tyco
- Type designation: HSM2300
- Hardware version: UA623 Rev.01
- Software version: Ver. 1.14
- Serial number: N/A