CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7300-1273:0513
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita,Dan (905) 760-3020 Email: dan.nita@jci.com
DESIGN:	Model PG9945 Wireless Transmitter. Product is intended to be used as a wireless transmitter in household fire applications. In this case, the auxiliary input is to be connected to System Sensor's separately Listed self-restoring heat detector models. The heat detector shall be installed in the same room and the length of the wiring shall be limited to 3 ft. Only one detector can be connected to one transmitter. The reed switch operation shall be disabled. All transmissions from the RF transmitter send battery status information to the panel with transmissions occurring at approximately 915 MHz (912 to 919 MHz). Intended for indoor use only and can be installed on metallic and nonmetallic surfaces. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	3 VDC Battery Type Installed: GP/Panasonic CR123A
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, and UL label.

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

APPROVAL:	Listed as a control unit accessory for use with separately listed compatible household fire alarm control units and separately listed compatible heat detectors. Refer to listee's Installation Instruction Manual for details. Compatible Household Fire Alarm Control Unit: Tyco Safety Products Canada Ltd. - Models HS2128, HS2064, HS2032, and HS2016 (CSFM Listing No. 7167-1273:0153); Models WS900-19 and WS900-29 (CSFM Listing No. 7167-1273:0501); and Models HS3248, HS3128, and HS3032 (CSFM Listing No. 7167-1273:0507) Qolsys - Model IQPanel2 (CSFM Listing No. 7167-2142:0501) Qolsys - Model IQPanel4 (CSFM Listing No. 7167-2142:0505) Compatible Heat Detector: System Sensor - Models 5601P, 5602, 5621, and 5622 (CSFM Listing No. 7270-1653:0167)
NOTES:	

11-10-2021 DAL

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/04/2022

Listing Expires: 06/30/2023

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division