



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7300-1273:0514
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
<b>LISTEE:</b>	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita, Dan (647) 480-0430 (905) 760-3020 Email: dan.nita@jci.com
<b>DESIGN:</b>	Models TL880LEB and TL880LEC Ethernet/Cellular Alarm Communicator. Products are intended for use as primary (sole) or backup central station fire and burglar alarm system communicators, which employ cellular data communication as the signaling means. The Ethernet+LTE is considered a single communication pathway. The Ethernet or LTE cannot be programmed to work in individual Ethernet only or LTE only pathways. Intended for indoor use only.  Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	11.3-12.5 VDC
<b>INSTALLATION:</b>	In accordance with listee's installation instructions, NFPA 70, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as ethernet/cellular alarm communicators for use with listee's separately listed compatible household fire alarm control units. Refer to listee's Installation Instruction Manual for details.  Compatible Household Fire Alarm Control Unit:  Tyco Safety Products Canada Ltd. - Models HS2128, HS2064, HS2032, and HS2016 (CSFM Listing No. 7167-1273:0153) and Models HS3248, HS3128, and HS3032 (CSFM Listing No. 7167-1273:0507)
<b>NOTES:</b>	Burglary and other non-fire functions were not examined.

11-29-21 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

**Date Issued: 05/03/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division