



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7272-1273:0518
PARENT LISTING No.:	7272-0026:0515
CATEGORY:	7272 - SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC
LISTEE:	Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, AL, L4K 4L2 Contact: Nita, Dan 6474800504 Email: dan.nita@jci.com
DESIGN:	<p>Model MX916 Multi-criteria, Smoke/Heat Detector Head, addressable intelligent type photoelectric smoke detector with 135 °F (57.2 °C) fixed temperature and 15 °F/min (8.3 °C/min) rate of rise.</p> <p>Model MX926 Single-criteria, Smoke and Duct Detector Head, addressable intelligent type photoelectric smoke detector.</p> <p>Refer to listee's printed data sheet for additional detailed product description and operational considerations.</p>
RATING:	<p>Voltage Range: 20-40 VDC</p> <p>Standby Current: 360 uA</p> <p>Alarm Current: 3.39 mA</p>
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as smoke detectors for use with listee's models IQ Pro and IQ Pro P (CSFM Listing No. 7167-1273:0516) fire alarm control units. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in UL 268, 7th Edition, UL 268A, 4th Edition, and UL 521, 7th Edition.
NOTES:	



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

8-1-22 DAL



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division