

Table of Contents

Section 1: Introduction	3
1.1 Before You Begin	3
1.2 How to Use This Manual	4
1.3 PC4164-NB Specifications	5
1.4 Wireless Devices	5
Section 2: Getting Started	6
2.1 Unpack the PC4164-NB	6
2.2 Find a Mounting Location for the PC4164-NB	6
2.3 Connecting the PC4164-NB	7
2.4 Enroll the PC4164-NB	8
Section 3: Enroll & Program Wireless Devices	9
3.1 A Note about Electronic Serial Numbers (ESN)	9
3.2 Enroll Wireless Devices using Zones (WLS904-NB and WLS907-NB)	9
3.3 Enroll and Program Wireless Keys (WLS909-NB)	10
Section 4: Testing & Mounting Devices	12
4.1 Test the Placement of WLS904-NB and WLS907-NB Devices	12
4.2 Test WLS909-NB Reception	13
4.3 Mount the PC4164-NB and Wireless Devices	13
Section 5: Deleting & Replacing Devices	14
5.1 Replacing Devices	14
5.2 Deleting Devices	15
5.3 Erasing Device Serial Numbers	15
Section 6: Additional Programming Notes	16
6.1 Device Supervision	16
6.2 Trouble Conditions	17
Section 7: Troubleshooting	19
Programming Worksheets	20
Index	23
Limited Warranty	24

WARNING Please Read Carefully

Note to Installers

This warning contains vital information. As the only individual in contact with system users, it is your responsibility to bring each item in this warning to the attention of the users of this system.

System Failures

This system has been carefully designed to be as effective as possible. There are circumstances, however, involving fire, burglary, or other types of emergencies where it may not provide protection. Any alarm system of any type may be compromised deliberately or may fail to operate as expected for a variety of reasons. Some but not all of these reasons may be:

■ **Inadequate Installation**

A security system must be installed properly in order to provide adequate protection. Every installation should be evaluated by a security professional to ensure that all access points and areas are covered. Locks and latches on windows and doors must be secure and operate as intended. Windows, doors, walls, ceilings and other building materials must be of sufficient strength and construction to provide the level of protection expected. A reevaluation must be done during and after any construction activity. An evaluation by the fire and/or police department is highly recommended if this service is available.

■ **Criminal Knowledge**

This system contains security features which were known to be effective at the time of manufacture. It is possible for persons with criminal intent to develop techniques which reduce the effectiveness of these features. It is important that a security system be reviewed periodically to ensure that its features remain effective and that it be updated or replaced if it is found that it does not provide the protection expected.

■ **Access by Intruders**

Intruders may enter through an unprotected access point, circumvent a sensing device, evade detection by moving through an area of insufficient coverage, disconnect a warning device, or interfere with or prevent the proper operation of the system.

■ **Power Failure**

Control units, intrusion detectors, smoke detectors and many other security devices require an adequate power supply for proper operation. If a device operates from batteries, it is possible for the batteries to fail. Even if the batteries have not failed, they must be charged, in good condition and installed correctly. If a device operates only by AC power, any interruption, however brief, will render that device inoperative while it does not have power. Power interruptions of any length are often accompanied by voltage fluctuations which may damage electronic equipment such as a security system. After a power interruption has occurred, immediately conduct a complete system test to ensure that the system operates as intended.

■ **Failure of Replaceable Batteries**

This system's wireless transmitters have been designed to provide several years of battery life under normal conditions. The expected battery life is a function of the device environment, usage and type. Ambient conditions such as high humidity, high or low temperatures, or large temperature fluctuations may reduce the expected battery life. While each transmitting device has a low battery monitor which identifies when the batteries need to be replaced, this monitor may fail to operate as expected. Regular testing and maintenance will keep the system in good operating condition.

■ **Compromise of Radio Frequency (Wireless) Devices**

Signals may not reach the receiver under all circumstances which could include metal objects placed on or near the radio path or deliberate jamming or other inadvertent radio signal interference.

■ **System Users**

A user may not be able to operate a panic or emergency switch possibly due to permanent or temporary physical disability, inability to reach the device in time, or unfamiliarity with the correct operation. It is important that all system users be trained in the correct operation of the alarm system and that they know how to respond when the system indicates an alarm.

■ **Smoke Detectors**

Smoke detectors that are a part of this system may not properly alert occupants of a fire for a number of reasons, some of which follow. The smoke detectors may have been improperly installed or positioned. Smoke may not be able to reach the smoke detectors, such as when the fire is in a chimney, walls or roofs, or on the other side of closed doors. Smoke detectors may not detect smoke from fires on another level of the residence or building. Every fire is different in the amount of smoke produced and the rate of burning. Smoke detectors cannot sense all types of fires equally well. Smoke detectors may not provide timely warning of fires caused by carelessness or safety hazards such as smoking in bed, violent explosions, escaping gas, improper storage of flammable materials, overloaded electrical circuits, children playing with matches or arson.

Even if the smoke detector operates as intended, there may be circumstances when there is insufficient warning to allow all occupants to escape in time to avoid injury or death.

■ **Motion Detectors**

Motion detectors can only detect motion within the designated areas as shown in their respective installation instructions. They cannot discriminate between intruders and intended occupants. Motion detectors do not provide volumetric area protection. They have multiple beams of detection and motion can only be detected in unobstructed areas covered by these beams. They cannot detect motion which occurs behind walls, ceilings, floor, closed doors, glass partitions, glass doors or windows. Any type of tampering whether intentional or unintentional such as masking, painting, or spraying of any material on the lenses, mirrors, windows or any other part of the detection system will impair its proper operation.

Passive infrared motion detectors operate by sensing changes in temperature. However their effectiveness can be reduced when the ambient temperature rises near or above body temperature or if there are intentional or unintentional sources of heat in or near the detection area. Some of these heat sources could be heaters, radiators, stoves, barbecues, fireplaces, sunlight, steam vents, lighting and so on.

■ **Warning Devices**

Warning devices such as sirens, bells, horns, or strobes may not warn people or waken someone sleeping if there is an intervening wall or door. If warning devices are located on a different level of the residence or premise, then it is less likely that the occupants will be alerted or awakened. Audible warning devices may be interfered with by other noise sources such as stereos, radios, televisions, air conditioners or other appliances, or passing traffic. Audible warning devices, however loud, may not be heard by a hearing-impaired person.

■ **Telephone Lines**

If telephone lines are used to transmit alarms, they may be out of service or busy for certain periods of time. Also an intruder may cut the telephone line or defeat its operation by more sophisticated means which may be difficult to detect.

■ **Insufficient Time**

There may be circumstances when the system will operate as intended, yet the occupants will not be protected from the emergency due to their inability to respond to the warnings in a timely manner. If the system is monitored, the response may not occur in time to protect the occupants or their belongings.

■ **Component Failure**

Although every effort has been made to make this system as reliable as possible, the system may fail to function as intended due to the failure of a component.

■ **Inadequate Testing**

Most problems that would prevent an alarm system from operating as intended can be found by regular testing and maintenance. The complete system should be tested weekly and immediately after a break-in, an attempted break-in, a fire, a storm, an earthquake, an accident, or any kind of construction activity inside or outside the premises. The testing should include all sensing devices, keypads, consoles, alarm indicating devices and any other operational devices that are part of the system.

■ **Security and Insurance**

Regardless of its capabilities, an alarm system is not a substitute for property or life insurance. An alarm system also is not a substitute for property owners, renters, or other occupants to act prudently to prevent or minimize the harmful effects of an emergency situation.

Introduction

S E C T I O N 1

The PC4164-NB is a wireless signal receiver for use with Maxsys PC4010 and PC4020 v3.0 panels. The PC4164-NB receives signals from WLS9XX wireless devices.

New features of the PC4164-NB v2.0:

- **Identification of Wireless Keys (WLS909-NB):** Wireless keys 1 to 16 can be identified as user numbers 0101 to 0116 (respectively) for identified openings/closings and command output activation. *For more information regarding this feature, see Section 3.3 “Enroll and Program Wireless Keys.”*
- **6 digit serial numbers for all wireless devices:** These new serial numbers include hexadecimal digits. *Please read Section 3.1 “A note on Electronic Serial Numbers (ESN)” for more information on enrolling older 5-digit and newer 6-digit devices.*

1.1 Before You Begin

This manual describes how to install, program and maintain the PC4164-NB on a PC4010/4020 Security System. You should have completed the following steps in your PC4010/4020 installation, before you install the PC4164-NB module:

1. Plan the installation and wiring of the PC4010/4020 system (see *PC4010/4020 Installation Manual, Section 2: Installation and Wiring*)
2. Install the control panel, and install and enroll at least one keypad to use for programming (see *PC4010/4020 Installation Manual, Section 3: How to Program*)
3. Install and enroll any hardwired zone expander modules (PC4108A or PC4116) you plan to use (see *PC4010/4020 Installation Manual, Section 4: Module Enrollment*).

You can program the PC4164-NB from a PC4010/4020 system LCD keypad or using downloading software on a remote computer. Read your system *Installation Manual, section 3 “How to Program”* for more information.

1.2 How to Use This Manual

To install and set up the PC4164-NB and wireless devices, follow these steps:

1. Enroll and temporarily mount the PC4164-NB module (see *Section 2*)
2. Enroll and program wireless devices using zones, wireless keys and handheld keypads (see *Section 3*)
3. Complete zone and other programming on the system (see *Sections 4 and 5*)
4. Test the placement of all the wireless devices (see *Section 6*)
5. Permanently mount the PC4164-NB receiver and wireless devices (see *Section 6*)

To replace or delete wireless devices already enrolled, see *Section 4*.

For additional information on wireless motion detectors and wireless keys, see *Sections 7 and 8*.

For help with troubleshooting, see *Section 9*.

Record the zone or slot and serial numbers of all wireless devices, and other programming in the *Programming Worksheets* section at the end of the manual.

PC4010/4020 Programming

All programming sections in this manual are referred to by reference number. A detailed description of PC4010/4020 programming is in the PC4010/4020 Installation Manual, section 3 "How to Program."

To program using reference numbers, enter Installer's programming ([*][8][Installer's Code]). Press and hold the [A]uxiliary key until the keypad displays the following message:

"Enter Ref # then *."

Enter the reference number found in the programming Worksheets for the section you wish to program, then press the [*] key. The display will immediately go to the programming item you have selected.

1.3 PC4164-NB Specifications

- One PC4164-NB receiver may be installed per PC4010/4020 system
- Nominal current draw of 80mA
- Frequency: 434 MHz
- Receives signals from up to 56 wireless zones on a PC4010 v3.0 and later, and up to 64 wireless zones on a PC4020 v3.0 and later
- Antenna - diversity design for enhanced performance
- Programmable supervisory window, 01:00 to 23:59
- Location
 - can be wired up to 750 ft. / 230 m from the main panel with 22 gauge wire
 - connects to Combus
 - for longer wire runs, thicker gauge wire must be used.

1.4 Wireless Devices

Please refer to the Installation Instruction sheets of the following devices for more information.

The PC4164-NB v2.0 can receive signals from the following devices:

This unit is listed as a single or multiple station smoke detector accessory.

- WLS904-NB Motion Detector
- WLS907-NB Universal Transmitter
- WLS909-NB Wireless Key (up to 16)

Batteries

The wireless devices are designed to use Eveready Alkaline Energizer batteries only.

NOTE: *Do not use other brands of batteries. Using any other brand voids any approvals and may affect the system operation.*

Getting Started

S E C T I O N 2

This section describes how to set up and enroll the PC4164-NB module.

2.1 Unpack the PC4164-NB

Check that the following parts are in your PC4164-NB package:

- PC4164-NB PCB
- PC4164-NB plastic cabinet
- 2 antennas

2.2 Find a Mounting Location for the PC4164-NB

NOTE: Do not permanently mount the PC4164-NB now. Mount the PC4164-NB receiver **after** you have done placement tests with all the wireless devices (see sections 4.1 and 4.2).

Find a place that is:

- Dry
- Central to the proposed placement of all wireless devices
- As high as possible
- Far from sources of interference, including: electrical noise such as computers, televisions and electric motors in appliances and heating and air conditioning units; large metal objects like heating ducts and plumbing which may shield the antenna.

Make sure that electrical wires will not run over the antenna(s) of the module when it is mounted.

When mounting the PC4164-NB in a basement, place the module as high and as close to the underside of the first floor as possible. The range of the module will be smaller if the unit is mounted below ground level.

2.3 Connecting the PC4164-NB

The PC4164-NB is connected to the control panel via the Combus.

CAUTION: Remove all power from the panel while connecting modules to the Combus.

Wire the PC4164-NB to the Combus of the PC4010/PC4020 according to diagram 1:




Diagram 1

2.4 Enroll the PC4164-NB

You must enroll the PC4164-NB module with the PC4010/4020 panel, before you can install and program the WLS9XX devices. The PC4164-NB will reserve up to 56 zones on a PC4010 and up to 64 zones on a PC4020 for wireless use.

To make sure you have enough space for hardwire zones, you should enroll the PC4164-NB after you have enrolled all the hardwire zone expander modules. For example, if you enroll the PC4164-NB first on a PC4020, it would use up zones 17 to 80, leaving only 48 spots left for hardwire zone expander modules.

NOTE: *You cannot have more than 64 zones on the PC4010 and 128 zones on the PC4020. If the total number of zones theoretically available on the zone expanders exceeds the maximum for the panel, you will not be able to use the extra zones.*

A description of how to enroll keypads and modules is in your PC4010/4020 Installation Manual, section 4: Module Enrollment.

Follow these steps to enroll your PC4164-NB module.

1. At a PC4010/4020 system LCD keypad, enter [*][8][Installer's code] to go to the Installer's Programming section.
2. Enter Ref #[0200], to go to the **Enroll Module** section.
3. Scroll to **PC41XX Zn. Ex.**, press [*]. The LCD keypad will display **Create Tamper on Desired Unit**.
4. Tamper the PC4164-NB:
 - i) make sure the connection between the T1 and T2 tamper terminals is closed (tamper zone secured) (see Diagram 1).
 - ii) open the normally closed contact, if present, or remove the wiring from one of the tamper terminals (tamper zone violated). The change from secure to violated will enroll the module.

The LCD keypad will display **PC4164-NB Zn. Ex. Mod XX Enrolled**.

5. When the module is enrolled, re-secure the connection between the T1 and T2 terminals.
6. Press [#]. The LCD keypad will display **Zones XXX - XXX**. Record the zone number range for the module in the worksheets.
7. To exit module enrollment, press [#].

The PC4164-NB module is now installed and enrolled on the PC4010/4020 system. You can now enroll and program the wireless devices. How to do this is described in Section 3.

Enroll & Program Wireless Devices

S E C T I O N 3

This section describes how to enroll and program:

- wireless devices using zones (WLS904-NB and WLS907-NB)
- wireless keys (WLS909-NB)

For more information on these devices, read the instruction sheet included with each device.

3.1 A Note about Electronic Serial Numbers (ESN)

In order to reduce the occurrence of wireless devices with the same serial number, 6-digit serial numbers are now printed on the back of each wireless device. The 6-digit serial numbers include hexadecimal digits. For instructions on programming hexadecimal numbers, see your *PC4010/4020 Installation manual, section 3: How to Program*.

Older wireless devices will only have 5-digit serial numbers. To enroll these devices, enter [0], then the 5-digit serial number.

3.2 Enroll Wireless Devices using Zones (WLS904-NB and WLS907-NB)

NOTE: Before you permanently mount wireless devices, test each one in its intended mounting location to make sure that it can communicate properly with the PC4164-NB. Test the device 2-3 times. See Section 4.1 for more information.

1. At a system LCD keypad, enter [*][8][Installer's code].
2. Enter Ref #[001300] to go to the **Enroll Device** programming section.

This section will only be available if you have enrolled the PC4164-NB with the panel (see Section 2.5).

The LCD keypad will display **Enroll Device Serial # []**.

3. Look at the back of the first wireless device you want to enroll. If the device has a 6-digit serial number, enter it now. If the device only has a 5-digit number, enter a [0] and then the 5-digit number.
4. The LCD keypad will briefly show **Enroll Device Zone XXX**, where XXX = the zone number the device is assigned to on the control panel.

Record the serial number and assigned zone number in the programming worksheets in the back of this manual.

5. The LCD keypad will display **Enroll Device Serial # []**. Continue with steps 3 – 4 until all devices have been enrolled.
6. To exit device enrollment, press [#].

Program Partitions and Zones

Now that you have enrolled and mounted the wireless devices, you should program your PC4010/4020 partitions and zones. See your *PC4010/4020 Installation Manual, section 5: Partitions and Zones*.

3.3 Enroll and Program Wireless Keys (WLS909-NB)

For wireless keys to work on the system, you need to enroll them and then program the function buttons. You can enroll up to 16 wireless keys on the PC4164-NB.

Step 1: Enroll Wireless keys

1. At a PC4010/4020 system LCD keypad, enter [*][8][Installer’s code] to go to the Installer’s Programming section.
2. Enter Ref #[001300], to go to the **Enroll Device** programming section. This section will only be available if you have enrolled the PC4164-NB with the panel (see *Section 2.6*). The LCD keypad will display
Enroll Device Serial # [].
3. Look at the back of the wireless key. If it has a 6-digit serial number, enter it now. If it only has a 5-digit number, enter a [0] and then the 5-digit number.
4. The display will show **Enroll Device WKEY #XX**, where XX = the Wkey slot to which the WLS909-NB is assigned (01 to 16).
5. Record the serial number and assigned slot number in the programming worksheets in the back of this manual.
6. Continue with steps 3 – 5 until all wireless keys have been enrolled.

Wireless Key Reporting

When you enroll a wireless key, the panel will assign a user number (0101 to 0116) to the key. The wireless key enrolled in slot 01 will be given user number 0101, slot 02 will have user number 0102, and so on. This allows the panel to transmit and log the arm/disarm events performed by each wireless key.

You can still program access codes for user numbers 0101 to 0116.

For example:

User 0101 arms or disarms using an access code - the panel transmits and logs *Closing/Opening User 0101*.

A user arms or disarms using wireless key 01 - the panel transmits *Closing/Opening User 0101* and logs *Closing/Opening User 0101 AND Closing/Opening WKey #01*.

Step 2: Program the WLS909-NB Function Buttons

WLS909-NB wireless keys have four programmable function buttons. When you press and hold a button for two seconds, the programmed function will be executed. Each function button can be assigned to one partition.

NOTE: *Wireless key function buttons will not work when the partition(s) they are assigned to are being accessed for zone bypassing or programming.*

1. From Installer’s Programming, enter Ref#[001304], to go to **WLSKey Functions**.
2. Scroll to the slot number of the key you want to program (01-16). Press [*].
3. Scroll to the number of the button you want to program (1-4). Press [*].
4. Enter the 2-digit number of the function you want to select, or scroll to the function you want to assign to that button and press [*]. The following functions may be programmed:

00 Null Key	07 Arm Interior
01 Stay Arm	08-15 [*][7] Command Outputs 1-8
02 Away Arm	16 Fire Alarm
03 No-Entry Arm	17 Auxiliary Alarm
04 Chime On/Off	18 Panic Alarm
05 System Test	19 Disarm (Off)
06 Quick Exit	

NOTE: *If programmed, these options do not require access code entry regardless of other system options. The programmed function will be executed immediately.*

5. The LCD keypad will show **Select (01) Partition 1**. Scroll to the partition you want the button to work in, and press [*] to select.
6. Repeat steps 3 to 5 until all the buttons are programmed.
7. Repeat steps 4 to 6 until all the wireless keys are programmed.
8. To exit, press [#].

NOTE: *When a Wireless Key is used to disarm a partition, all courtesy pulse outputs enabled for that partition will activate for two minutes.*

Now that you have enrolled and programmed all the wireless devices, you will need to test the devices and mount wireless devices using zones. See section 4 for more information.

Testing & Mounting Devices

S E C T I O N 4

You should test each device you have enrolled to ensure good signal strength between the devices and the PC4164-NB. Follow the instructions in this section to test wireless devices which use zones, wireless keys and handheld keypads.

If several wireless devices produce BAD test results, you may need to move the PC4164-NB to a better location. (See section 2.3 for tips on finding a location for the PC4164-NB.)

4.1 Test the Placement of WLS904-NB and WLS907-NB Devices

It is very important to test each wireless device before it is mounted. Following these steps will test the placement of WLS904-NB and WLS907-NB wireless devices, based on the signal strength between the PC4164-NB and the device:

NOTE: *You cannot test the Wireless Key (WLS909-NB) in this mode. See section 4.2 for instructions on testing this device.*

1. Temporarily place the device in its intended mounting location.
2. At a system LCD keypad, enter [*][8][Installer's code].
3. Enter Ref # [001303] to go to the **Device Test** section.
4. Enter [00] to have test results sounded on the keypad buzzers only. Enter [01] to have test results sounded by the system bells, as well as the keypad buzzers.
5. Use the [<][>] keys to scroll to the device and press [*] to select it. The keypad will display **Activate Device**.
6. Activate the device being tested. A result will be displayed on the keypad or sounded by the keypad or bell.

WLS904-NB: Remove the detector from its backplate, wait for 5 seconds, then reattach the detector to its backplate.

WLS907-NB: Open and close the contact by moving the magnet away from the unit. If the unit is attached to a door or a window, open and close the door or window to activate the device.

7. Read the test results:

Placement	LCD Keypad Display	Keypad Buzzer/ Bells
Good	Good	1 Beep/squawk
Fair	Fair	2 Beeps/squawks
Bad	Bad	3 Beeps/squawks

Activate the device until you get 3 good or fair results in a row. Wait 10 seconds between each test on the same device. You may mount wireless devices where results were good or fair.

Devices indicating a bad result must be moved to another location. You may only have to move the device a few inches to correct a bad result.

NOTE: Do not mount any device where a “bad” test result was indicated.

If several wireless devices produce BAD test results, you may need to move the PC4164-NB to a better location. (See section 2.3 for tips on finding a location for the PC4164-NB.)

8. To test another device, press [#] once, then repeat steps 4 - 7. Continue to test the devices until both the PC4164-NB and the devices are in good or fair locations.
9. To exit installer programming, press [#].

4.2 Test WLS909-NB Reception

The wireless key (WLS909-NB) cannot be tested using the module placement test described above. To ensure that the PC4164-NB is receiving transmissions from these devices, conduct the following tests:

Use the function keys to arm and disarm the system at several different points in the installation.

NOTE: Do not use a Fire, Auxiliary or Panic key to test your WLS909-NB as pressing these buttons will always notify your central station of a non-medical emergency.

If these devices do not operate from all points in the installation, you will need to move the PC4164-NB receiver. Moving the PC4164-NB higher will usually improve the reception.

If you move the PC4164-NB, repeat the tests described in sections 4.1 and 4.2 on all the wireless devices. Continue to test the devices until you have found locations with good or fair placement results for the PC4164-NB and the WLS904-NB and WLS907-NB devices, and there is acceptable range between the PC4164-NB and the WLS909-NB devices.

4.3 Mount the PC4164-NB and Wireless Devices

Do not permanently mount the PC4164-NB until you have tested reception with all the wireless devices (see sections 4.1 and 4.2). Once you have done this and have a good location, mount the PC4164-NB:

1. Remove the four screws that attach the PC4164-NB to the plastic cabinet.
2. Pull the Combus wires through the hole at the back of the cabinet.
3. Mount the cabinet securely to the wall.
4. Reattach the PC4164-NB to the mounted cabinet using the four mounting screws.

Mount the WLS904-NB and WLS907-NB Devices

If you have conducted the placement test described in section 4.1 and got 3 “Good” or “Fair” results in a row for each device, you can mount the wireless devices. See the Installation sheet for each device for mounting instructions.

Deleting & Replacing Devices

S E C T I O N 5

If a device is not working, or you need to change the setup of the system, you may need to replace or delete wireless devices. Follow the appropriate procedure in this section.

5.1 Replacing Devices

Wireless devices are divided into the following classes:

Class	Model
2	WLS907-NB
3	WLS904-NB
6 & 9	WLS909-NB

This section describes how to replace one device with another device of the same class. All programming that was used with the old device will be used with the new device. For example, a WLS907-NB can be replaced with a WLS907-NB.

1. At a system LCD keypad, enter [*][8][Installer's code].
2. Enter Ref #[001302] to go to the **Replace Device** section. The LCD keypad will display
Serial # [] and either
Zone XXX, Wkey# XX or **HHK# XX**
3. Use the [<][>] keys to scroll to the device to be deleted, then press [*]. The LCD keypad will display
With Device
Serial# [].
4. Enter the serial number of the new device. The LCD keypad will display **Device Replaced Serial # [] Zone XXX**

NOTE: You cannot replace devices of different classes. (For example, a motion detector cannot be replaced by a universal transmitter.) If you need to do this, you must delete the first device (see *Deleting Devices*, below) and enroll the second. You will also need to change the programming for the new device. See Section 3: *Installing WLS9XX Wireless Devices*.

NOTE: To change the partition a handheld keypad is assigned to, you must delete and then re-enroll the keypad.

5. To exit, press [#].

5.2 Deleting Devices

This section describes how to delete any of the enrolled wireless devices from the PC4164-NB, and from the system.

1. At a system LCD keypad, enter [*][8][Installer's code].
2. Enter Ref #[001301] to go to the **Delete Device** section. The LCD keypad will display
Serial # [] and either
Zone Label XXX, Wkey# XX or **HHK# XX**
3. Use the [<][>] keys to scroll to the device you want to delete, then press [*]. The bottom line of the display will read **Device Deleted**.
4. To exit, press [#].

When you enroll a new device, the serial number will fill the first available empty zone, key or keypad slot. For example, if zones 017 to 019 and 021 to 023 are used, but zone 020 is empty, the next device enrolled will be placed in zone number 020.

If you enroll a device of the same class as the one deleted (See Replacing Devices, above) it will be placed in the old device's slot.

Make sure you update the programming for each device you enroll.

5.3 Erasing Device Serial Numbers

Entering this programming section will erase the serial numbers of all the wireless devices.

Zone and partition programming will not be affected. When you re-enroll the wireless devices, remember to change the zone and partition programming, if necessary.

1. At a LCD keypad, enter [*][8][Installer's code].
2. Enter Ref #[001308], or scroll to **Default Wireless** and press [*].
3. The LCD will display **Confirm Default Press ***. To confirm the default procedure, press [*]. To cancel the default procedure, press any other key.

Additional Programming Notes

S E C T I O N 6

6.1 Device Supervision

When supervision of a wireless device on a zone is turned ON, the panel will show a trouble if a wireless zone stops working or is removed from the system. When supervision is turned OFF, the panel will not show a trouble.

NOTE: *Wireless Keys are NOT supervised.*

A *zone supervisory* is a test transmission that each wireless zone sends to the PC4164-NB. When the PC4164-NB receives the supervisory transmission from the zone, the PC4164-NB will transmit this information to the control panel.

If the control panel does not get a supervisory transmission from a zone within the Device Fail time, the zone will be considered “missing” causing a Device Fault.

The next supervisory transmission that the PC4164-NB receives from the “missing” zone will restore communication with that zone and restore the Zone Supervisory Fault. The Device Fail timer will also be reset.

Change the Supervision Option

1. At a LCD keypad, enter [*][8][Installer’s code].
2. Enter Ref #[001306] to go to the **Supv Window** section.
3. Devices are listed by zone number in the order in which they were enrolled. Scroll to each device. Press [*] to turn the supervision option ON or OFF for that device.
4. To exit, press [#].

Change the Device Fail Time

The default amount of time is 3 hours.

1. At a LCD keypad, enter [*][8][Installer’s code].
2. Enter Ref #[001307] to go to the **Device Fail Time** section.
3. Enter the time as [HHMM] (valid entries 01:00 - 23:59).
4. To exit, press [#].

6.2 Trouble Conditions

The PC4010/4020 always watches for possible trouble conditions. If a trouble condition occurs, the LCD keypad “Trouble” light will turn on and the keypad will beep. Press [*][2] to display the trouble conditions.

The following trouble conditions apply to the PC4164-NB. For a description of all troubles, please see *Section 16 “Diagnostics and Troubleshooting”* in the PC4010/4020 Installation Manual.

- PC4164 Tamper
- RF Jam Detected (see below)
- Device Fault (see section 6.1)
- Smoke Low Sense
- Device Low Batt

Wireless Device Low Battery Trouble Transmission Delay

When a device reports a low battery trouble, the keypad will indicate the trouble immediately, but the panel will delay transmission of the trouble to the monitoring station. You can program the length of the delay (in days) in Installer’s programming. If the user does not correct the low battery condition before the delay expires, the low battery trouble will be transmitted.

The low battery alarm and restore codes will only be reported once per armed period. The Low Battery Restore transmission is not delayed. The default transmission delay is 7 days.

To change the transmission delay:

1. At a LCD keypad, enter [*][8][Installer’s code].
2. Enter Ref #[00040211] to go to the **4164 Low Bat Dly** section.
3. Enter the new transmission delay (from 000 to 255 days).
4. To exit, press [#].

Replacing Batteries in Wireless Devices

1. Remove the cover of the device from its back plate. This creates a tamper condition on the zone.
2. Refer to the battery installation instructions on the installation sheet of each component. Be sure to note the proper orientation of the batteries as you install them.
3. When the fresh batteries are in place, re-attach the cover to the back plate. The tamper is restored and the zone sends a battery trouble restoral signal to the PC4164-NB. The battery trouble is now clear.

NOTE: *When batteries in one device need to be replaced, the batteries in all devices should be replaced at the same time.*

Enable RF Jam Detect Trouble

The RF Jam Detect trouble condition will be generated and logged when the PC4164-NB module detects an attempt to block RF signals. This tells the user that the PC4164-NB is not receiving wireless device transmissions. The panel will transmit the General System Trouble reporting code.

The default setting for this option is OFF. To enable warning of this trouble condition:

1. At a LCD keypad, enter [*][8][Installer's code].
2. Enter Ref #[000200] to go to the **System Toggles** section.
3. Scroll to **RF Jam Detect**.
4. Press [*] to toggle the option ON or OFF.
5. To exit System Toggles, press [#].

Troubleshooting

S E C T I O N 7

1. When I enter [0013] PC4164 options, the keypad gives me a long beep.

You cannot enter ESNs unless the PC4164-NB wireless receiver is enrolled. See section 2 for instructions on enrolling the PC4164-NB module.

2. I have entered the ESN for the device but when I violate the device, the zone does not show open on the keypad.

Check the following:

- Check that you are looking at a keypad on the same partition as the device you are testing
- Check that the ESN has been entered correctly
- Check that the zone is assigned to one or more partitions.

3. When I try a module placement test I get no result or “Bad” results.

Check the following (see sections 4.1 and 4.2 for more information on testing devices):

- Verify that you are testing the correct zone
- Verify that the correct ESN was entered when the device was enrolled
- Verify that the device is in range of the PC4164-NB. Try testing the device in the same room as the receiver.
- Confirm that the PC4164-NB is properly connected to the Combus (see section 2 for PC4164-NB set up and wiring instructions).
- Check that you are testing the zone correctly (see sections 4.1 and 4.2 for testing instructions)
- Check that the batteries are working and installed correctly.
- Look for large metal objects that may be preventing the signal from reaching the PC4164-NB.

The device must be located where consistent “Good” or “Fair” results are obtained. If several devices show “Bad” results, or if panic pendants and wireless keys operate inconsistently, move the receiver. See section 2.3 for tips on choosing a mounting location for the PC4164-NB.

4. The LED on the motion detector does not turn on when I walk in front of the unit.

The LED is for walk test purposes only. See your WLS904-NB instruction sheet for walk test instructions.

Programming Worksheets

S E C T I O N 4

[001300] *Enroll Device (see section 3.2)*

- Default = 000000
- 6-digit entry is required; for 5-digit serial numbers, enter [0], then the number (See section 3.1 "A Note About Electronic Serial Numbers".)

System Zone	PC4164 Zone	Serial No.	System Zone	PC4164 Zone	Serial No.
_____	1	_____	_____	33	_____
_____	2	_____	_____	34	_____
_____	3	_____	_____	35	_____
_____	4	_____	_____	36	_____
_____	5	_____	_____	37	_____
_____	6	_____	_____	38	_____
_____	7	_____	_____	39	_____
_____	8	_____	_____	40	_____
_____	9	_____	_____	41	_____
_____	10	_____	_____	42	_____
_____	11	_____	_____	43	_____
_____	12	_____	_____	44	_____
_____	13	_____	_____	45	_____
_____	14	_____	_____	46	_____
_____	15	_____	_____	47	_____
_____	16	_____	_____	48	_____
_____	17	_____	_____	49	_____
_____	18	_____	_____	50	_____
_____	19	_____	_____	51	_____
_____	20	_____	_____	52	_____
_____	21	_____	_____	53	_____
_____	22	_____	_____	54	_____
_____	23	_____	_____	55	_____
_____	24	_____	_____	56	_____
_____	25	_____	_____	57	_____
_____	26	_____	_____	58	_____
_____	27	_____	_____	59	_____
_____	28	_____	_____	60	_____
_____	29	_____	_____	61	_____
_____	30	_____	_____	62	_____
_____	31	_____	_____	63	_____
_____	32	_____	_____	64	_____

PC4020 only

WLS909-NB Wireless Key Options (see section 3.3)

[001300] *Enroll Device* Default = 000000

Wireless Key No.	Serial No.	Wireless Key No.	Serial No.
01	_____	09	_____
02	_____	10	_____
03	_____	11	_____
04	_____	12	_____
05	_____	13	_____
06	_____	14	_____
07	_____	15	_____
08	_____	16	_____

[001304] *Wireless key Functions* Default = 00

Key No.	Button 1	Partition No.*	Button 2	Partition No.*	Button 3	Partition No.*	Button 4	Partition No.*
01	__	__	__	__	__	__	__	__
02	__	__	__	__	__	__	__	__
03	__	__	__	__	__	__	__	__
04	__	__	__	__	__	__	__	__
05	__	__	__	__	__	__	__	__
06	__	__	__	__	__	__	__	__
07	__	__	__	__	__	__	__	__
08	__	__	__	__	__	__	__	__
09	__	__	__	__	__	__	__	__
10	__	__	__	__	__	__	__	__
11	__	__	__	__	__	__	__	__
12	__	__	__	__	__	__	__	__
13	__	__	__	__	__	__	__	__
14	__	__	__	__	__	__	__	__
15	__	__	__	__	__	__	__	__
16	__	__	__	__	__	__	__	__

*enter partition number 1-8

Wireless Key Function Key Options

00	Null Key	07	Arm Interior
01	Stay Arm	08-15	[*][7] Command Outputs 1-8
02	Away Arm	16	Fire Alarm
03	No-Entry Arm	17	Auxiliary Alarm
04	Chime On/Off	18	Panic Alarm
05	System Test	19	Disarm (Off)
06	Quick Exit		

Index

A

- Add
 - device 9
 - wireless key 10
- Antenna 5

B

- Batteries
 - replacing 17
 - type 5
- Buttons
 - programming 11

C

- Connect
 - Combus 7
 - PC4164-NB 7

D

- Default Wireless 15
- Deleting devices 15
- Devices
 - adding 9
 - deleting 15
 - replacing 14
- Distance
 - from control panel 5

E

- Electronic serial number 9
- Enroll
 - device 9
 - module 8
 - wireless key 10
- ESN. *See Electronic serial number*

F

- Frequency 5

I

- Interference 6

L

- Location
 - choosing 6
- Low battery devices 17

M

- Motion detector
 - test 12
- Mount
 - devices 13
 - PC4164-NB 13

N

- Number
 - serial 9
 - slot 10
 - zone 9
- Numbers
 - reference 4

P

- Partition programming
 - for buttons 11
- Placement
 - PC4164-NB 6
 - test 12
- Power 7
- Problems 19
- Programming
 - how to 4

R

- Reference numbers 4
- Remove
 - devices 15
- Replace
 - devices 14

S

- Serial numbers 9
 - erasing 15
- Slot number
 - wireless key 10
- Supervision 16

T

- Testing
 - door/window
 - contact 12
 - motion detector 12
 - wireless key 13
- Trouble conditions 17
- Troubleshooting 19

W

- Wireless key
 - enrolling 10
 - identifying 10
 - programming 11
 - reporting 10

Z

- Zone
 - adding 9
 - numbers 8

LIMITED WARRANTY

Digital Security Controls Ltd. warrants the original purchaser that for a period of twelve months from the date of purchase, the product shall be free of defects in materials and workmanship under normal use. During the warranty period, Digital Security Controls Ltd. shall, at its option, repair or replace any defective product upon return of the product to its factory, at no charge for labour and materials. Any replacement and/or repaired parts are warranted for the remainder of the original warranty or ninety (90) days, whichever is longer. The original owner must promptly notify Digital Security Controls Ltd. in writing that there is defect in material or workmanship, such written notice to be received in all events prior to expiration of the warranty period.

International Warranty

The warranty for international customers is the same as for any customer within Canada and the United States, with the exception that Digital Security Controls Ltd. shall not be responsible for any customs fees, taxes, or VAT that may be due.

Warranty Procedure

To obtain service under this warranty, please return the item(s) in question to the point of purchase. All authorized distributors and dealers have a warranty program. Anyone returning goods to Digital Security Controls Ltd. must first obtain an authorization number. Digital Security Controls Ltd. will not accept any shipment whatsoever for which prior authorization has not been obtained.

Conditions to Void Warranty

This warranty applies only to defects in parts and workmanship relating to normal use. It does not cover:

- damage incurred in shipping or handling;
- damage caused by disaster such as fire, flood, wind, earthquake or lightning;
- damage due to causes beyond the control of Digital Security Controls Ltd. such as excessive voltage, mechanical shock or water damage;
- damage caused by unauthorized attachment, alterations, modifications or foreign objects;
- damage caused by peripherals (unless such peripherals were supplied by Digital Security Controls Ltd.);
- defects caused by failure to provide a suitable installation environment for the products;
- damage caused by use of the products for purposes other than those for which it was designed;
- damage from improper maintenance;
- damage arising out of any other abuse, mishandling or improper application of the products.

Digital Security Controls Ltd.'s liability for failure to repair the product under this warranty after a reasonable number of attempts will be limited to a replacement of the product, as the exclusive remedy for breach of warranty. Under no circumstances shall Digital Security Controls Ltd. be liable for any special, incidental, or consequential damages based upon breach of warranty, breach of contract, negligence, strict liability, or any other legal theory. Such damages include, but are not limited to, loss of profits, loss of the product or any associated equipment, cost of capital, cost of substitute or replacement equipment, facilities or services, down time, purchaser's time, the claims of third parties, including customers, and injury to property.

Disclaimer of Warranties

This warranty contains the entire warranty and shall be in lieu of any and all other warranties, whether expressed or implied (including all implied warranties of merchantability or fitness for a particular purpose) And of all other obligations or liabilities on the part of Digital Security Controls Ltd. Digital Security Controls Ltd. neither assumes nor authorizes any other person purporting to act on its behalf to modify or to change this warranty, nor to assume for it any other warranty or liability concerning this product.

This disclaimer of warranties and limited warranty are governed by the laws of the province of Ontario, Canada.

WARNING: Digital Security Controls Ltd. recommends that the entire system be completely tested on a regular basis. However, despite frequent testing, and due to, but not limited to, criminal tampering or electrical disruption, it is possible for this product to fail to perform as expected.

Installer's Lockout

Any products returned to DSC which have the Installer's Lockout option enabled and exhibit no other problems will be subject to a service charge.

Out of Warranty Repairs

Digital Security Controls Ltd. will at its option repair or replace out-of-warranty products which are returned to its factory according to the following conditions. Anyone returning goods to Digital Security Controls Ltd. must first obtain an authorization number. Digital Security Controls Ltd. will not accept any shipment whatsoever for which prior authorization has not been obtained.

Products which Digital Security Controls Ltd. determines to be repairable will be repaired and returned. A set fee which Digital Security Controls Ltd. has predetermined and which may be revised from time to time, will be charged for each unit repaired.

Products which Digital Security Controls Ltd. determines not to be repairable will be replaced by the nearest equivalent product available at that time. The current market price of the replacement product will be charged for each replacement unit.



©1999 Digital Security Controls Ltd.
1645 Flint Road, Downsview, Ontario, Canada M3J 2J6
(416) 665-8460 • 1-800-387-3630
www.dscgrp.com

Printed in Canada 29004102 R001

MAXSYS™

PC4164-NB v2.0 • Installation Manual

WARNING: *This manual contains information on limitations regarding product use and function and information on the limitations as to liability of the manufacturer. The entire manual should be carefully read.*

FCC COMPLIANCE STATEMENT

CAUTION: CHANGES OR MODIFICATIONS NOT EXPRESSLY APPROVED BY DIGITAL SECURITY CONTROLS LTD. COULD VOID YOUR AUTHORITY TO USE THIS EQUIPMENT.

This equipment generates and uses radio frequency energy and if not installed and used properly, in strict accordance with the manufacturer's instructions, may cause interference to radio and television reception. It has been type tested and found to comply with the limits for Class B device in accordance with the specifications in Subpart "B" of Part 15 of FCC Rules, which are designed to provide reasonable protection against such interference in any residential installation. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause interference to television or radio reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Re-orient the receiving antenna
- Relocate the alarm control with respect to the receiver
- Move the alarm control away from the receiver
- Connect the alarm control into a different outlet so that alarm control and receiver are on different circuits.

If necessary, the user should consult the dealer or an experienced radio/television technician for additional suggestions. The user may find the following booklet prepared by the FCC helpful: "How to Identify and Resolve Radio/Television Interference Problems". This booklet is available from the U.S. Government Printing Office, Washington, D.C. 20402, Stock # 004-000-00345-4.

This device complies with RSS-210 of Industry Canada. Operation is subject to the following two conditions: (1) this device may not cause interference, and (2) this device must accept any interference, including interference that may cause undesired operation of the device.

Ce dispositif satisfait aux exigences d'Industrie Canada, prescrites dans le document CNR-210. son utilisation est autorisée seulement aux conditions suivantes: (1) il ne doit pas produire de brouillage et (2) l'utilisateur du dispositif doit être prêt à accepter tout brouillage radioélectrique reçu, même si ce brouillage est susceptible de compromettre le fonctionnement du dispositif.