



UTOUC.S4019 Household Fire Warning System Units

[Page Bottom](#)

Household Fire Warning System Units

[See General Information for Household Fire Warning System Units](#)

DIGITAL SECURITY CONTROLS, DIV OF TYCO SAFETY PRODUCTS CANADA LTD
95 BRIDGELAND AVE
TORONTO, ON M6A 1Y7 CANADA

S4019

Household fire warning control units, Input: 16.5 V ac, 60 Hz, 37 VA (using Class 2 limited energy transformers). All units must have ULC-LA "Power On" light kit.

DSC Series

Models	Current	Remote Keypads
PC1500, PC1550, PC2500,	0.07 A	LCD600 (T), PC1500 (RK, RKF)
PC2525, PC2550, PC3000		
PC1575	0.07 A	KP5500 (T, Z, ZT), KP5506 (T), LCD5500 (T, Z, ZT),
		PC5506 (T), PC1575RK
PC4010 (AR, CF, CFAR),	0.08 A	LCD4500/01 (T)
PC4020 (AR, CF, CFAR)		LCD4501Z(T)
PC5008, PC1555, PC1555MX	0.07 A	KP5500, KP5508, LCD5500, PC1555RKZ
PC1565		
PC5010 (NKU), PC5015, PC5020	0.07 A	KP5500 (T, Z, ZT), KP5508/16/32 (T, Z, ZT),
		LCD5500 (T, Z, ZT)
NT9005-433	0.1A	N/A
NT9010-433	0.10 A	N/A

Combus accessories, PC4108(A), PC4116, PC4164RS, PC4204, PC4216, PC4216A, PC4400, EscortPC4580, PC4612, PC4632, PC4664, PC4700, PC4701, PC4702BP, PC4820, PC4936 and PC4937, Input: 11.6-12.6 V dc. TS-VPM4580, Input: 12 Vdc, 10 mA (max). Power Supply Module, Models PC4204CXCF, PC4204CX, Input: Primary, 120 V ac, 0.48 A, 60 Hz.

Serial Output modules: Models PC4401, KT4401VK.

Accessory Module (Ethernet Communicator) for Central and Monitoring Station Fire and/or Burglary, and Household Fire and/or Burglary, Models T-Link TL250, T-Link TL300.

Keybus accessories, PC5100, PC5108(D,L), PC5132RS, PC5200, PC5204, NT9204, PC5208, PC5400, Escort 5580(TC), PC5700, PC5720, PC5921/2/3 (EXT/R), PC5904, PKP-ICM, PC5928, PC5936, PC5937, DLM-4L, KP5501Z(T), KP5506(T,Z,ZT), LCD5501Z(T), LCD5501Z32-900, LCD5501Z32-433, RF5501-433, Input: 11.6-12.6 V dc, 260 mA (max) and PC5502Z2(T), PKP-400, PKP-LCD, PKP-ICON, Input: 11.6-12.6 V dc. TS-VPM5580TC for local access only, Input: 12 V dc, 10 mA (max.). HS-HC8000, Input: 12 V ac, 500 mA (max.). Models LCD5511, LED5511, Input : 12 V dc, 85 mA.

Control unit accessories, PK5500, PK5501, PK5508, PK5516, RFK5500-433, RFK5501-433, RFK5508-433, RFK5516-433, RFK5564-433, PTK5507. For use with separately Listed compatible control units as indicated in the installation instructions.

Addressable accessories: AMP-701, Input: 11.6-12.6 V dc, 0.8 mA; compatible with PC5100, PC4010 Series and PC4020 Series; AMP-702 and AMP-750, Input: 5 V dc, 0.9 mA (maximum) compatible with AMP-704 Point Interface Module, Input: 12 V dc, 6.7 mA max, compatible with PC4020, PC4020 CF V3.0++, PC5015 V2.2++, PC5020/PC5020 CF V3.0++ (++ denotes required PC5100 Addressable Expansion Module). LCD5501Z, Input: 12 V dc, 85 mA max. Model ADT-AC communicator board to be used with listed and labeled ADT Focus D50 Subscribers' Control Unit Fire/Burglary PC5400 DVAC module and ADT receivers 2980, C2990 or C2995.

Westec kit: Combination household fire and burglar alarm system consisting of PC4020 v3.1 control unit, LCD4503Z keypad/audio station, PC4580 voice assisted security module, PC4936 audio interface module, PC4937 audio expansion module and PC4056C enclosure, Input: 16.5 V ac, 60 Hz, 40 VA (using Class 2, limited energy transformer).

Remote sounder, Model NT9201, Input: 6 V dc, 12 mA (Standby), 170 mA (Alarm), provided from NT9010-433 control unit.

Partner Series

Models	Current	Remote Keypad and Current
P6	0.07 A	RS6, PRS6, PRS6L, 0.06 A
P6B, P6BM, P48	0.07 A	PRS6RKZ
P6BMX	0.07A	PKP-LCD, PKP-ICON
P600	0.07 A	PRS600 (T), 0.03 A
P864 (CB, CBCF, CF),	0.08 A	PRS400 (T), 0.06 A
P16128 (CB, CBCF, CF)		
PAMP702, PAMP750	0.9 mA	KP5500
PNT9010-433	0.10 A	N/A

Keybus accessories: P5100, P5108(D,L), P5132-900, P5132RS, P5208, P5400, P5580(TC), P5700, P5720, P5921/2/3 (EXT/R), P5904, P5928, P5936, P5937, DLM-4, P832-02Z(T) , P832-ICON and P-ICON-900, Input: 11.6-12.6 V dc.

Combus accessories: P4108(A), P4116, P4164RS, P4204, P4216, P4216A, P4400, P4580, P4612, P4632, P4664, P4700, P4701, P4702, P4820, P4936 and P4937, Input: 11.6-12.6 V dc. PC5102-433 Wireless Receiver for wireless keys only. Input: 11.6-12.6 V dc, 200 mA max. Keybus RF Accessory: Model RF5108-433 Wireless Receiver and Control unit accessories: Models RF5132-433 and RF4164-433 RF receivers. Model TR5164-433 receiver and transmitter. For use with other separately compatibly Listed devices as indicated in the manufacturer's installation instructions, Input: 12 V dc, 40 mA max.

RF accessories: WLS908, WLS909 and WLS910 (battery operated); compatible with PC5132-900 and PC5132RS. (Note: WLS910 cannot be used as primary keypad). PWLS908, PWLS909 and PWLS910 keypads (battery operated); compatible with P5132 and P4164. WLS919-433 keypads (battery operated), compatible with the PC132-433 and NT9010-433.

Addressable accessories: PAMP-700, Input: 11.6-12.6 V dc, 0.8 mA, compatible with P5100, P864 Series and P16128 Series.

Westec kit: Combination household fire and burglar alarm system consisting of P16128A v3.1 control unit, PEKP keypad/audio station, P4580 voice assisted security module, P4936 audio interface module, P4937 audio expansion module and P4056C enclosure, Input: 16.5 V ac, 60 Hz, 40 VA (using Class 2, limited energy transformer).

Remote sounder, Model PNT9201, Input: 6 V dc, 12 mA (Standby), 170 mA (Alarm), provided from NT9010-433 control unit.

Power Reversal Modules: Model PRM-2W and PRM-2W(C), Input: 12-15 V dc, 25 mA max, Model PRM-4W and PRM-4W(C), Input: 12-15 V dc, 25 mA max.

Power Supervisory Relay: Model RM-2, Input: 10-30 V dc, 25 mA max.

Control unit accessories, Models GS3055-I, GS3060 and GS3060-RF GSM-GPRS Interfaces, Fire Alarm and Security Equipment, intended for supplementary use only with separately Listed control units as indicated in the installation instructions. For models GS3055-I and GS3060, internal 12V, minimum 1.2 AH rechargeable battery is required for Low Power Mode (JP3 OFF); Model GS3060-RF employs a 12 V/7.0 Ah battery.

Control unit accessory: Fire Alarm and Security Equipment Model GS-BOOST Telco Voltage Booster, used only in conjunction with Model GS3060 when interfacing with alarm control panels that require a higher simulated Telco line voltage.

Control unit accessories, Models 3G3070 and 3G3070-RF GSM-GPRS/3G Interfaces, intended for supplementary use only with separately Listed control units as indicated in the installation instructions. For model 3G3070, internal 12V, minimum 1.2 AH rechargeable battery is required for Low Power Mode (JP3 OFF); Model 3G3070-RF employs a 12 V/7.0 Ah battery.

Control unit accessories, Model 3G4010 GSM-GPRS/3G Alarm Communicator.

Control unit subassembly, Model 3G3070 PCB Assembly, intended for supplementary use only with separately Listed control units as indicated in the installation instructions. Internal 12V, minimum 1.2 AH rechargeable battery is required for Low Power Mode (JP3 OFF).

Control unit subassembly, Model 3G4010 PCB Assembly.

Model Security Gateway/GTW5000: Combination household fire and burglary warning systems with integrated PC5020 combination control unit,

LCD5501Z32-433, RF5501-433 and/or LCD5500Z keypads, PC5936 audio interface module, PC5904 and/or PC5921, PC5921EXT, PC5921EXT/R audio stations, HS-NH400 10 Base T Ethernet hub, 4110 video module, AXT Terminal Expansion Module and MN12165 March Networks PS, Input: 120 V ac, 60 Hz, 175 Va.

Household fire warning control units, Input: 16.5 V ac, 60 Hz, 37 VA (using Class 2 limited energy transformers). All units must have ULC-LA "Power On" light kit. DSC Series: Models PC1864, PC1832 and PC1616.

Household fire warning control units, Models SCW9047-433, SCW9447-433, SCW9045-433, Input: 16 V ac, 60 Hz, 20 VA (from Class 2 limited energy transformers).

Combination household burglary and fire alarm system control units, Models PC9155-433, PC9155D-433, PC9155G-433, PC9155I-433 short range low power RF and hardwire system; Models SCW9055-433, SCW9055D-433, SCW9055G-433, SCW9055I-433, SCW9055D-SM-433, SCW9055G-SM-433, SCW9055I-SM-433, SCW9057-433, SCW9057D-433, SCW9057G-433, SCW9057I-433, SCW9057D-SM-433, SCW9057G-SM-433, SCW9057I-SM-433 short range low power RF and hardwire systems with integrated sounder.

Models PC580, PC585, Power432 Input: 16.5 V ac, 60 Hz, 40 VA (from Class 2 transformer).

Combination household fire and burglary alarm system control unit, Input: 16.5 V ac, 60 Hz, 37 VA (using Class 2 limited energy transformers). DSC: Model PC1404.

Control unit accessories, Keypad, PC1404RKZ. For use with separately Listed compatible control units as indicated in the installation instructions.

Models WT5500-433, WT5500P-433 Wireless Keypad, WT4901 Wireless Indoor Siren for use with PC9155 and SCW9055/9057 Wireless systems.

Model WS4920 RF repeater.

Models HS2LCD, HS2LCDP, HS2ICN, HS2ICNP, HS2LED, HS2TCHP Keypads. Models HS2LCDRF9, HS2LCDRFP9, HS2ICNRF9, HS2ICNRF9P Keypads with RF receiver. Model HSM2HOST9 RF Receiver, Model PG9920 RF Repeater. Models PG9901, PG9911 Wireless Sirens. All Accessories are compatible with Models HS2128, HS2064, HS2032, HS2016 alarm controllers only.

Models HS2LCDWFPV9, HS2LCDWFP9 and HS2LCDWF9, wireless keypad. For use with Listed Combination Control Units, Models HS2128, HS2064, HS2032, HS2016, when used in conjunction with the compatible Wireless Transceiver Model HSM2HOST9, Model PG9920 RF Repeater or Keypads with integrated wireless transceiver models HS2LCDRF(P)9 or HS2ICNRF(P)9.

Model PC5961E Small Audio Station, Model PC5964E Large Audio Station.

Control unit accessories (3G cellular alarm communicators), Models 3G4000, 3G4000RF Communicators, for use with separately listed control units as indicated in installation instructions.

Models 3G8080 and 3G8080I Communicators, for use with separately listed control units as indicated in installation instructions.

Control unit accessories (CDMA cellular alarm communicators), Models CD8080 and CD8080I Communicators, for use with separately listed control units as indicated in installation instructions.

Control unit subassemblies, Models TL260GS, TL260GS-SM, TL260GS-RS, TL265GS, TL2553G-SM-NA, TL2553G-NA, TL255GS-SM-NA, TL2603GR, TL2803GR, TL2603G, TL2803G, TL255GS-NA, TL2753G, IP/GSM-GPRS Communicators; Models TL260, TL280, TL260R, TL280R, TL260-SM, TL260-RS, TL265, TL255-SM-NA, TL255, TL275 IP Communicators and Models GS2060, GS2060-SM, GS2060-RS, GS2065, GS2055-SM-NA, GS2055-NA, 3G2055-SM-NA, 3G2060R, 3G2060, 3G2080, 3G2080R, 3G2055-NA, 3G2075, GSM-GPRS Communicator, for use with separately Listed Control Units as indicated in the Installation Instructions. Wi-Fi interface, Model WiFi422SCW.

Model PCL-422 TLINK communicator expander. For use exclusively with Models TL2803GR, TL2803G IP/GSM-GPRS Dual Alarm Communication Interface, 3G2080, 3G2080R GSM-GPRS Alarm Communication Interface, TL280, TL280R IP Alarm Communication Interface.

Models HS2128(&), HS2064(&), HS2032(&), HS2016(&) (Alarm Controller), Models HSM2300(&), HSM2204(&) (Power Supply), Model HSM2108 (Zone expander), Model HSM2208 (PGM Output Module), Models HSM2955 and HSM2955R Audio Verification Interface.

Models 3G8055, 3G8055I, CD8055, CD8055I @, Communicators, for use with separately listed control units as indicated in installation instructions.

Control unit subassemblies (3G cellular alarm communicators), Models 3G8055 NEO and 3G8055I NEO Communicators.

Control unit subassemblies (CDMA cellular alarm communicators), Models CD8055 NEO and CD8055I NEO Communicators.

Fire alarm and security subassembly, Models TL2803G, TL2803GR IP/GSM-GPRS Dual Alarm Communication Interface, 3G2080 GSM-GPRS Alarm Communication Interface, TL280R, TL280 IP Alarm Communication Interface, suitable for use as a household fire and burglary warning system subassembly, and as a commercial burglar alarm system control unit subassembly. Model PCL-422 Communicator expansion interface board.

Household fire and burglar alarm system control unit accessories, Wireless Keypad Models WTK5504P-433, WTK5504-433.

@: Investigated to Clauses 8.4.2 and 8.16 of CAN/ULC-S527

Last Updated on 2015-06-04

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2015 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2015 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

