

# Online Directories

[Quick Guide](#) [OD Home](#) [Contact Us](#) [ULC.ca](#)

## DAYRC.S7513 Central Station Fire Alarm System Units

[Page Bottom](#)

### Central Station Fire Alarm System Units

[See General Information for Central Station Fire Alarm System Units](#)

**DIGITAL SECURITY CONTROLS, DIV OF TYCO SAFETY PRODUCTS** S7513  
**CANADA LTD**  
 3301 LANGSTAFF RD  
 CONCORD, ON L4K 4L2 CANADA

Subscriber's fire alarm control units, Input: 16.5 V ac, 60 Hz, 37 VA (using Class 2 limited energy transformers). All units have ULC LA "Power On" light kit and tamper switch kit T 1 installed in the certified installation. DSC Series:

Models	Current, A	Models	Current, A
PC4010(AR,CF,CFAR), PC4020(AR,CF,CFAR) ,	0.08	PC4400, PC4700	0.062, 0.035
PC5008, PC1555, PC1555MX, PC1565, PC48	0.07	PC5400	0.062
PC5010(NKU), PC5015, PC1575, PC5020(CF)	0.07	PC5400, PC5720, PC5700	0.062

Combus Accessories: PC4108(A), PC4116, PC4164RS, PC4204, PC4216, PC4400, PC4401, EscortPC4580, PC4612, PC4632, PC4664, PC4700, PC4701, PC4702BP, PC4820; PC4936 and PC4937 keypads, Models, LCD4500(T) and LCD4501(T), Input: 11.6 12.6 V dc. TS-VPM450, Input: 12 Vdc, 10 mA (max). Power Supply Module, Models PC4204CXCF, PC4204CX, Input: Primary, 120 V ac, 0.48 A, 60 Hz.

Accessory Module: The Ethernet Communicator Module, Model T-Link, Input: 11.6-12.6 V dc, 150.0 mA max.

The Network Internet Communicator Module, Model T-Link TL250, Input: 11.6-12.6 V dc, 250.0 mA. Output Protocols: UDP/IP 10/100 Base half duplex, Input Protocols: PC-Link, DVACS.

Keybus Accessories: PC5100, PC5108(D,L), PC5132RS, PC5200, PC5204, PC5208, PC5400, Escort 5580(TC), PC5700, PC5720, PC5921/2/3 (EXT/R), PC5904, PC5928, P5936, P5937 and DLM 4; keypads, KP5500(T,Z,ZT), KP55012(T), KP5506(T,Z,ZT) KP5508/16/32(T,Z,ZT), LCD5500(T,Z,ZT), LCD55012(T), PC5502Z2, PC5508/16/32(T,Z,ZT), PC1555RKZ and PC1575RKZ, Input: 11.6 12.6 V dc. TS-VPM5580TC for local access only, Input: 12 V dc, 10 mA (max.). Model LCD5511, Input: 12 V dc, 85 mA max.

Addressable Accessories: AMP 700, Input: 11.6 12.6 V dc, 0.8 mA; compatible with PC5100, PC4010 Series and PC4020 Series. Partner Series:

<b>Models</b>	<b>Current, A</b>	<b>Communication Modules</b>	<b>Current</b>
P6B, P6BM, P48, P6BMX	0.07	P5400	0.062 A
P600, P832(DL)	0.07	P5400, P5720, P5700	0.062 A; 11.6 12.6 V dc
P864(CB,CBCF,CF) P16128(CBCF,CBCF)	0.08	P4400, P4700	0.062 A; 0.035 A; 11.6 12.6 V dc

Keybus Accessories: P5100, P5108(D,L), P5132(RS, 900), P5200, P5204, P5208, P5400, P5580(TC), P5700, P5720, P5921/2/3 (EXT/R), P5904, P5928, P5936, P5937 and DLM 4; keypads, PRS600(T), P832 08/16/32(T,Z,ZT), P832 LCD(T,Z,ZT), P832-022(T) and P832-ICON, Input: 11.6 12.6 V dc.

Combus Accessories: P4108(A), P4116, P4204, P4216, P4400, P4580, P4612, P4632, P4664, P4700, P4701, P4702, P4820, P4936 and P4937; keypad PRS400, Input: 11.6 12.6 V dc.

RF Accessories: WLS908, WLS909 and WLS910 (battery operated); compatible with PC5132 900, PC5132RS and PC4164. (Not to be used for fire alarm initiating purposes). PWLS908, PWLS909 and PWLS910 keypads (battery operated); compatible with P5132 and P4164. WLS919-433 keypads (battery operated), compatible with the PC132-433 and NT9010-433.

Addressable Accessories: PAMP 700, Input: 11.6 12.6 V dc, 0.8 mA, compatible with P5100, P864 Series and P16128 Series. Model SG-SYSTEM III c/w SG-DRL3, SG-CPM3, SG-PSU3 switchboard units-fire and/or burglary, Input: 120 V, 60 Hz, 2.5 A.

Accessories: Model ADT AC communicator board to be used with ULC listed and labelled ADT Focus D50 subscribers' control unit fire/burglary PC5400 DVAC module and ADT receivers 2980, C2990 or C2995.

Transceiver Board - Model Skyroute Max, Input: 12 V dc, 1.3 A (transmitting) for use with the following control units: DSC Model PC4020 (CF)/Partner P-16128.

Transceiver Board - Model Skyroute, Input: 12 V dc, 1.3A (transmitting) for use with the following control units: DSC PC5010/Partner P-832, software version VI-xx, V2.xx or higher, DSC PC1555/Partner P-6B, software version V2.xx and higher, DSC PC580/Partner P-48, software version V2.xx and higher, DSC PC5015/Partner P-832DL software version VI-xx, V2.2xx and higher, DSC PC5020/Partner P-8+, software version V3.xx and higher. Model Skyroute CL3050, max, Input: 12 V dc, 0.5 A per use with the following control units: DSC Model PC5108.

Model Security Gateway/GTW5000: Combination household fire and burglary warning systems with integrated PC5020 combination control unit, LCD5501Z32-433, RF5501-433 and/or LCD5500Z keypads, PC5936 audio interface module, PC5904 and/or PC5921, PC5921EXT, PC5921EXT/R audio stations, HS-NH400 10 Base T Ethernet hub, 4110 video module, AXT Terminal Expansion Module and MN12165 March Networks PS, Input: 120 V ac, 60 Hz, 175 Va.

Model SG-System II, digital alarm communicator receiver, suitable for encrypted line security when provided with subassembly Models T-Link TL250, SG-DRL3-IP.

Thermal Printer for Central Station Use, Model DPU-414-30B.

Model SG-System I, digital alarm communicator receiver, suitable for level passive communication system when use with Listed DACT and transmitter Models T-Link TL250/300, GS3055-I or GS3060, also suitable for active communication system when use only with Listed Active Transmitters TL-250 and TL-300. Input: 120 V ac, 60 Hz, 0.7A.

[Copyright © 2009 Underwriters' Laboratories of Canada®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the Online Certifications Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories of Canada" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2009 Underwriters Laboratories of Canada®"

An independent organization working for a safer world with integrity, precision and knowledge.

